

*Compliance Designs*

**CLIENT:** Fox Ledge Inc.  
1432 Bethany Turnpike  
Honesdale, PA 18431

**DATE OF REPORT:** Quarter 1, 2025  
**REPORT #:** 107-21338  
**LABORATORY ID#:** 380-131110-1

**NOTE:** “\*\*” indicates that maximum levels have been exceeded, or in the case of pH, is either too high or too low  
“ND” indicates that none of this analyte has been detected at or above the specified detection level  
“MCL” indicates maximum contaminant level as established by US FDA for bottled water  
“RL” indicates laboratory reporting limit for method  
Units results are reported in mg/L unless otherwise noted

ANALYSIS PERFORMED	MCL <sup>1</sup> (mg/L)	RL (mg/L)	SPRING FINISHED PRODUCT (Produced from Spring 1, 1.5 Liter, Line 1) 107-21338 (mg/L)
<b>Primary Inorganics</b>			
Antimony	0.006	0.002	ND
Arsenic	0.01	0.002	ND
Asbestos	7 MFL	0.177	ND
Barium	2	0.002	0.026
Beryllium	0.004	0.0003	ND
Cadmium	0.005	0.0005	ND
Chromium	0.1	0.0009	ND
Cyanide	0.2	0.025	ND
Fluoride	See endnote <sup>2</sup>	0.05	ND
Lead	0.005	0.0005	ND
Mercury	0.002	0.0002	ND
Nickel	0.1	0.001	ND
Nitrate – N	10	0.05	0.78
Nitrite – N	1.0	0.05	ND
Total Nitrate & Nitrite – N	10	0.05	0.78
Selenium	0.05	0.002	ND
Thallium	0.002	0.0003	ND
<b>Secondary Inorganics</b>			
Alkalinity	--	2	31
Aluminum	0.2	0.02	ND
Bicarbonate	--	2	31
Boron	--	0.05	ND
Bromide	--	0.005	0.0079
Calcium	--	0.10	12
Carbonate	--	2	ND
Chloride	250 <sup>3</sup>	0.50	1.3
Copper	1	0.001	0.002
Corrosivity	--	-14	-2.2
Foaming Agents	--	0.1	ND
Hardness, Calcium	--	2.5	30
Hardness, Total	--	2.9	34
Iron	0.3 <sup>3</sup>	0.01	ND
Magnesium	--	0.1	0.89
Manganese	0.05 <sup>3</sup>	0.002	ND
pH	See endnote <sup>4</sup>	0.01	6.5
Phenol	0.001	0.001	ND
Potassium	--	0.10	0.41
Silver	0.1	0.0005	ND
Sodium	--	0.10	1.9
Specific Conductance	-- umho/cm	2.0	79
Sulfate	250	0.25	4.2
TDS	500 <sup>3,5</sup>	10	44
Zinc	5 <sup>3</sup>	0.02	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	SPRING FINISHED PRODUCT (Produced from Spring 1, 1.5 Liter, Line 1) 107-21338 (mg/L)
<b>Physical</b>			
Color	15 <sup>3</sup> CU	2	3.0
Odor	3 <sup>3</sup> TON	1	ND
Turbidity	5 NTU	0.1	0.10
<b>Radiologicals</b>			
Gross Alpha	15 pCi/L	3	ND
Gross Beta	50 pCi/L <sup>5</sup>	4	ND
Radium 226/228	5 pCi/L	1 / 1	ND / ND
Uranium	0.030	0.001	ND
<b>Volatile Organic Compounds</b>			
<b>EPA 524.2:</b>			
Total Trihalomethanes	0.080	0.0005	ND
tert-Amyl Methyl Ether (TAME)	--	0.003	ND
tert-Butyl-Ethyl Ether (TBEE)	--	0.003	ND
Benzene	0.005	0.0005	ND
Bromobenzene	--	0.0005	ND
Bromochloromethane	--	0.0005	ND
Bromodichloromethane	--	0.0005	ND
Bromoform	--	0.0005	ND
Bromomethane	--	0.0005	ND
n-Butylbenzene	--	0.0005	ND
sec-Butylbenzene	--	0.0005	ND
tert-Butylbenzene	--	0.0005	ND
Carbon Disulfide	--	0.0005	ND
Carbon Tetrachloride	0.005	0.0005	ND
Chlorobenzene	0.1	0.0005	ND
Chloroethane	--	0.0005	ND
Chloroform	--	0.0005	ND
Chloromethane	--	0.0005	ND
2-Chlorotoluene	--	0.0005	ND
4-Chlorotoluene	--	0.0005	ND
Chlorodibromomethane	--	0.0005	ND
Dibromomethane	--	0.0005	ND
1,2-Dichlorobenzene	0.6	0.0005	ND
1,3-Dichlorobenzene	--	0.0005	ND
1,4-Dichlorobenzene	0.075	0.0005	ND
Dichlorodifluoromethane	--	0.0005	ND
1,1-Dichloroethane	--	0.0005	ND
1,2-Dichloroethane	0.005	0.0005	ND
1,1-Dichloroethylene	0.007	0.0005	ND
cis-1,2-Dichloroethylene	0.07	0.0005	ND
trans-1,2-Dichloroethylene	0.1	0.0005	ND
1,2-Dichloropropane	0.005	0.0005	ND
1,3-Dichloropropane	--	0.0005	ND
2,2-Dichloropropane	--	0.0005	ND
1,1-Dichloropropene	--	0.0005	ND
cis-1,3-Dichloropropene	--	0.0005	ND
trans-1,3-Dichloropropene	--	0.0005	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	SPRING FINISHED PRODUCT (Produced from Spring 1, 1.5 Liter, Line 1) 107-21338 (mg/L)
<b>EPA 524.2 continued:</b>			
Di-Isopropyl Ether	--	0.003	ND
Ethylbenzene	0.7	0.0005	ND
Hexachlorobutadiene	--	0.0005	ND
Isopropylbenzene	--	0.0005	ND
4-Isopropyltoluene	--	0.0005	ND
Methyl tert-Butyl Ether (MTBE)	--	0.0005	ND
Methyl Ethyl Ketone (MEK)	--	0.005	ND
Methylene Chloride	0.005	0.0005	ND
Naphthalene	--	0.0005	ND
n-Propylbenzene	--	0.0005	ND
Styrene	0.1	0.0005	ND
1,1,1,2-Tetrachloroethane	--	0.0005	ND
1,1,2,2-Tetrachloroethane	--	0.0005	ND
Tetrachloroethylene	0.005	0.0005	ND
Toluene	1	0.0005	ND
1,2,3-Trichlorobenzene	--	0.0005	ND
1,2,4-Trichlorobenzene	0.07	0.0005	ND
1,1,1-Trichloroethane	0.2	0.0005	ND
1,1,2-Trichloroethane	0.005	0.0005	ND
Trichloroethylene	0.005	0.0005	ND
Trichlorofluoromethane	--	0.0005	ND
Trichlorotrifluoroethane	--	0.0005	ND
1,2,3-Trichloropropane	--	0.0005	ND
1,2,4-Trimethylbenzene	--	0.0005	ND
1,3,5-Trimethylbenzene	--	0.0005	ND
Vinyl Chloride	0.002	0.0003	ND
m+p-Xylenes	--	0.0005	ND
ortho-Xylene	--	0.0005	ND
Total Xylene	10	0.0005	ND
<b>Add'l Organics</b>			
<b>EPA 504.1:</b>			
Ethylene Dibromide	0.00005	0.00001	ND
Dibromochloropropane	0.0002	0.00001	ND
1,2,3-Trichloropropane	--	0.00002	ND
<b>EPA 505:</b>			
Chlordane (alpha and gamma)	0.002	0.0001	ND
Total PCBs	0.0005	0.0001	ND
PCB 1016	--	0.00007	ND
PCB 1221	--	0.0001	ND
PCB 1232	--	0.0001	ND
PCB 1242	--	0.0001	ND
PCB 1248	--	0.0001	ND
PCB 1254	--	0.0001	ND
PCB 1260	--	0.00007	ND
Toxaphene	0.003	0.0005	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	SPRING FINISHED PRODUCT (Produced from Spring 1, 1.5 Liter, Line 1) 107-21338 (mg/L)
<b>EPA 515.4:</b>			
Acifluorfen	--	0.0002	ND
Bentazon	--	0.0005	ND
2,4-D	0.07	0.0001	ND
2,4-DB	--	0.002	ND
Dalapon	0.2	0.001	ND
Dicamba	--	0.0001	ND
3,5-Dichlorobenzoic Acid	--	0.0005	ND
Dichlorprop	--	0.0005	ND
Dinoseb	0.007	0.0002	ND
Pentachlorophenol	0.001	0.00004	ND
Picloram	0.5	0.0001	ND
2,4,5-T	--	0.0002	ND
2,4,5-TP (Silvex)	0.05	0.0001	ND
<b>EPA 525.2:</b>			
Acenaphthene	--	0.0001	ND
Acenaphthylene	--	0.0001	ND
Acetochlor	--	0.0001	ND
Alachlor	0.002	0.00005	ND
Aldrin	--	0.00001	ND
Alpha-BHC	--	0.0001	ND
Anthracene	--	0.00002	ND
Atrazine	0.003	0.00005	ND
Benz(a)Anthracene	--	0.00005	ND
Benzo(a)Pyrene	0.0002	0.00002	ND
Benzo(b)Fluoranthene	--	0.00002	ND
Benzo(g,h,i)Perylene	--	0.00005	ND
Benzo(k)Fluoranthene	--	0.00002	ND
Beta-BHC	--	0.0001	ND
Bromacil	--	0.0001	ND
Butylbenzylphthalate	--	0.0005	ND
Butachlor	--	0.00005	ND
Chlordane (alpha)	0.002	0.00005	ND
Chlordane (gamma)	0.002	0.00005	ND
Chlorobenzilate	--	0.0001	ND
Chloroneb	--	0.0001	ND
Chlorothalonil	--	0.0001	ND
Chlorpyrifos	--	0.00005	ND
Chrysene	--	0.00002	ND
Delta-BHC	--	0.0001	ND
4,4-DDD	--	0.0001	ND
4,4-DDE	--	0.0001	ND
4,4-DDT	--	0.0001	ND
Diazinon (Qualitative)	--	0.0001	ND
Dichlorvos (DDVP)	--	0.00005	ND
Di(2-ethylhexyl)Adipate	0.4	0.0006	ND
Dibenz(a,h)Anthracene	--	0.00005	ND
Di(2-ethylhexyl)Phthalate	0.006	0.0006	ND
Dieldrin	--	0.00001	ND
Diethylphthalate	--	0.0005	ND
Dimethylphthalate	--	0.0005	ND
Dimethoate	--	0.0001	ND
Di-n-Butylphthalate	--	0.001	ND
Di-n-Octylphthalate	--	0.0001	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	SPRING FINISHED PRODUCT (Produced from Spring 1, 1.5 Liter, Line 1) 107-21338 (mg/L)
<b>EPA 525.2 continued:</b>			
2,4-Dinitrotoluene	--	0.0001	ND
2,6-Dinitrotoluene	--	0.0001	ND
Endosulfan I (Alpha)	--	0.0001	ND
Endosulfan II (Beta)	--	0.0001	ND
Endosulfan Sulfate	--	0.0001	ND
Endrin	0.002	0.00001	ND
Endrin Aldehyde	--	0.0001	ND
EPTC	--	0.0001	ND
Fluoranthene	--	0.0001	ND
Fluorene	--	0.00005	ND
Heptachlor	0.0004	0.00001	ND
Heptachlor Epoxide	0.0002	0.00001	ND
Hexachlorobenzene	0.001	0.00005	ND
Hexachlorocyclopentadiene	0.05	0.00005	ND
Indeno(1,2,3-cd)Pyrene	--	0.00005	ND
Isophorone	--	0.0005	ND
Lindane	0.0002	0.00001	ND
Malathion	--	0.0001	ND
Methoxychlor	0.04	0.00005	ND
Metolachlor	--	0.00005	ND
Metribuzin	--	0.00005	ND
Molinate	--	0.0001	ND
Naphthalene	--	0.0001	ND
trans-Nonachlor	--	0.00005	ND
Parathion	--	0.0001	ND
Pendimethalin	--	0.0001	ND
Phenanthrene	--	0.00004	ND
Propachlor	--	0.00005	ND
Pyrene	--	0.00005	ND
Simazine	0.004	0.00005	ND
Terbacil	--	0.0001	ND
Terbutylazine	--	0.0001	ND
Thiobencarb	--	0.0001	ND
Trifluralin	--	0.0001	ND
<b>EPA 531.2:</b>			
Aldicarb (TEMIK)	--	0.0005	ND
Aldicarb sulfone	--	0.0005	ND
Aldicarb sulfoxide	--	0.0005	ND
Baygon (PROPOXUR)	--	0.0005	ND
Carbaryl	--	0.0005	ND
Carbofuran (FURADAN)	0.04	0.0005	ND
3-Hydroxycarbofuran	--	0.0005	ND
Methiocarb	--	0.0005	ND
Methomyl	--	0.0005	ND
Oxamyl (VYDATE)	0.2	0.0005	ND
<b>EPA 547:</b>			
Glyphosate	0.7	0.006	ND
<b>EPA 548.1:</b>			
Endothall	0.1	0.005	ND
<b>EPA 549.2:</b>			
Diquat	0.02	0.0004	ND
Paraquat	--	0.002	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	SPRING FINISHED PRODUCT (Produced from Spring 1, 1.5 Liter, Line 1) 107-21338 (mg/L)
<b>EPA 1613:</b> 2,3,7,8-TCDD (DIOXIN)	3x10 <sup>-8</sup>	4.9x10 <sup>-9</sup>	ND
<b>Disinfection Byproducts</b> <b>EPA 300.1:</b> Bromate	0.010	0.001	0.0012
<b>EPA 300.1B:</b> Chlorite	1.0	0.010	ND
<b>EPA 552.3:</b> Bromochloroacetic acid	--	0.001	ND
Dibromoacetic acid	--	0.001	ND
Dichloroacetic acid	--	0.001	ND
Monobromoacetic acid	--	0.001	ND
Monochloroacetic acid	--	0.002	ND
Trichloroacetic acid	--	0.001	ND
Haloacetic Acids, Total	0.060	0.002	ND
<b>Disinfection Byproducts</b> <b>EPA 524.2:</b> Total Trihalomethanes	0.080	0.0005	ND
Bromodichloromethane	--	0.0005	ND
Bromoform	--	0.0005	ND
Chloroform	--	0.0005	ND
Chlorodibromomethane	--	0.0005	ND
<b>Residual Disinfectants</b> <b>SM4500-CL G:</b> Residual Chlorine, Free	--	0.05	0.050
Residual Chlorine, Total	4.0	0.05	ND
Chloramines	4.0	0.05	ND
<b>SM4500-CIO2-D:</b> Chlorine Dioxide	0.8	0.24	ND
<b>Miscellaneous</b> <b>EPA 331.0:</b> Perchlorate	--	0.0005	ND

EPA approved methods were used in all of the analyses and a listing is available upon request. These test results may be used for compliance purposes as required.

<sup>1</sup> The EPA, some State agencies and/or the IBWA may have established alternate MCLs for some of these analytes. Please refer to Federal, State and Industry codes.

<sup>2</sup> Fluoride MCL is determined by annual average of maximum daily air temperatures where the bottled water is sold. Refer to tables found in 21 CFR 165. The MCL for bottled water to which Fluoride has been added is 0.7 mg/L.

<sup>3</sup> Mineral water is exempt from allowable levels per 21 CFR 165.110(b)(3) and (4). The exemptions are aesthetically based allowable levels and do not relate to a health concern.

<sup>4</sup> MCL established by US FDA for waters that meet the US FDA definition of "Purified" is 5-7 pH Units per the USP XXIII Standards, as referenced in 21 CFR 165.

<sup>5</sup> The bottled water shall not contain beta particle and photon radioactivity from man-made radionuclides in excess of that which would produce an annual dose equivalent to the total body or any internal organ of 4 millirems per year calculated on the basis of an intake of 2 liters of the water per day (= 50 pCi/L).

 **ANALYTICAL REPORT****PREPARED FOR**

Attn: (107) Water Quality Manager  
Fox Ledge Inc.  
1432 Bethany Turnpike  
Honesdale, Pennsylvania 18431

Generated 2/14/2025 2:01:15 PM

**JOB DESCRIPTION**

107-21338  
Fox Ledge - Honesdale - Spring Finished Product

**JOB NUMBER**

380-131110-1

# Eurofins Eaton Analytical Pomona

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

## Compliance Statement

The report format being provided is not compliant with TNI (The NELAC Institute) Standards, and is a client-specific format

## Authorization



Generated  
2/14/2025 2:01:15 PM

Authorized for release by  
Rachelle Arada, Project Manager  
[Rachelle.Arada@et.eurofinsus.com](mailto:Rachelle.Arada@et.eurofinsus.com)  
(626)386-1106



E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**2646395: FOX LEDGE**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
2646395	1022	COPPER	170	0.002	012225	100		012125	E	0930	68565	380-131110-1	ARADAR_18
2646395	1024	CYANIDE (FREE) (IOC)	182	0.0	012725	100		012125	E	0930	68565	380-131110-1	ARADAR_16
2646395	1025	FLUORIDE (IOC)	107	0.0	012525	100		012125	E	1550	68565	380-131110-1	ARADAR_17
2646395	1030	LEAD	170	0.0	012225	100		012125	E	0930	68565	380-131110-1	ARADAR_19
2646395	1040	NITRATE	120	0.78	012125	100		012125	E	1056	68565	380-131110-1	ARADAR_14
2646395	1041	NITRITE	120	0.0	012125	100		012125	E	1056	68565	380-131110-1	ARADAR_15

**2646395: FOX LEDGE**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
2646395	1005	ARSENIC (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_22
2646395	1010	BARIUM (IOC)	170	0.026			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_23
2646395	1011	BROMATE	172	0.0012			012825	100		012125	E	0930	68565	380-131110-1	ARADAR_31
2646395	1015	CADMIUM (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_25
2646395	1020	CHROMIUM (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_26
2646395	1035	MERCURY (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_27
2646395	1036	NICKEL (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_28
2646395	1045	SELENIUM (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_29
2646395	1074	ANTIMONY (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_21





E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**2646395: FOX LEDGE**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
2646395	1075	BERYLLIUM (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_24
2646395	1085	THALLIUM (IOC)	170	0.0			012225	100		012125	E	0930	68565	380-131110-1	ARADAR_30
2646395	2005	ENDRIN (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_70
2646395	2010	LINDANE (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_75
2646395	2015	METHOXYCHLOR (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_76
2646395	2020	TOXAPHENE (SOC)	225	0.0			012425	100		012125	E	0930	68565	380-131110-1	ARADAR_36
2646395	2031	DALAPON (SOC)	203	0.0			013125	100		012125	E	0930	68565	380-131110-1	ARADAR_39
2646395	2032	DIQUAT (SOC)	235	0.0			012725	100		012125	E	0930	68565	380-131110-1	ARADAR_82
2646395	2033	ENDOTHALL (SOC)	233	0.0			012925	100		012125	E	0930	68565	380-131110-1	ARADAR_81
2646395	2034	GLYPHOSATE (SOC)	232	0.0			012825	100		012825	E	0841	68565	380-131110-1	ARADAR_80
2646395	2035	DI(2-ETHYLHEXYL)ADIPATE (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_69
2646395	2036	OXAMYL (VYDATE) (SOC)	231	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_79
2646395	2037	SIMAZINE (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_77
2646395	2039	DI(2-ETHYLHEXYL)PHTHALATE (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_68
2646395	2040	PICLORAM (SOC)	203	0.0			013125	100		012125	E	0930	68565	380-131110-1	ARADAR_42
2646395	2041	DINOSEB (SOC)	203	0.0			013125	100		012125	E	0930	68565	380-131110-1	ARADAR_40
2646395	2042	HEXACHLOROCYCLOPENTADIENE(SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_74
2646395	2046	CARBOFURAN (SOC)	231	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_78
2646395	2050	ATRAZINE (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_66
2646395	2051	ALACHLOR (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_65





E-Government Application for Drinking Water Program  
SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**2646395: FOX LEDGE**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
2646395	2063	2,3,7,8-TCDD (DIOXIN) (SOC)	229	0.0			012425	100		012125	E	0930	68565	380-131110-1	ARADAR_20
2646395	2065	HEPTACHLOR (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_71
2646395	2067	HEPTACHLOR EPOXIDE (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_72
2646395	2105	2,4-D (SOC)	203	0.0			013125	100		012125	E	0930	68565	380-131110-1	ARADAR_38
2646395	2110	2,4,5-TP SILVEX (SOC)	203	0.0			013125	100		012125	E	0930	68565	380-131110-1	ARADAR_37
2646395	2274	HEXACHLOROBENZENE (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_73
2646395	2306	BENZO(A)PYRENE (SOC)	222	0.0			013025	100		012125	E	0930	68565	380-131110-1	ARADAR_67
2646395	2326	PENTACHLOROPHENOL (SOC)	203	0.0			013125	100		012125	E	0930	68565	380-131110-1	ARADAR_41
2646395	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_46
2646395	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_52
2646395	2383	PCBS (SOC)	225	0.0			012425	100		012125	E	0930	68565	380-131110-1	ARADAR_35
2646395	2456	HALOACETIC ACIDS (HAA5)	208	0.0			012525	100		012125	E	0930	68565	380-131110-1	ARADAR_83
2646395	2931	1,2-DIBROMO-3-CHLOROPROP(SOC)	219	0.0			012525	100		012125	E	0930	68565	380-131110-1	ARADAR_32
2646395	2946	ETHYLENE DIBROMIDE (EDB) (SOC)	219	0.0			012525	100		012125	E	0930	68565	380-131110-1	ARADAR_33
2646395	2950	TRIHALOMETHANES (TTHM)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_62
2646395	2955	XYLENES - TOTAL (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_64
2646395	2959	CHLORDANE (SOC)	225	0.0			012425	100		012125	E	0930	68565	380-131110-1	ARADAR_34
2646395	2964	DICHLOROMETHANE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_53
2646395	2968	O-DICHLOROBENZENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_55
2646395	2969	P-DICHLOROBENZENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_56





E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**2646395: FOX LEDGE**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
2646395	2976	VINYL CHLORIDE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_63
2646395	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_45
2646395	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_60
2646395	2980	1,2-DICHLOROETHANE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_47
2646395	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_43
2646395	2982	CARBON TETRACHLORIDE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_50
2646395	2983	1,2-DICHLOROPROPANE(VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_48
2646395	2984	TRICHLOROETHYLENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_61
2646395	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_44
2646395	2987	TETRACHLOROETHYLENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_58
2646395	2989	CHLOROBENZENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_51
2646395	2990	BENZENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_49
2646395	2991	TOLUENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_59
2646395	2992	ETHYLBENZENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_54
2646395	2996	STYRENE (VOC)	221	0.0			020125	100		012125	E	0930	68565	380-131110-1	ARADAR_57
2646395	4002	GROSS ALPHA PARTICLE ACTIVITY	401	0.46	0.52900	0.524	012625	100		012025	E	1729	68540	380-131110-1	ARADAR_84





E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**2646395: FOX LEDGE**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
2646395	1094	ASBESTOS	009	0.0	013025	100		011425	E	0723	05265	3005978	ALTHOMPS ONL05265_8



# Case Narrative

Client: Fox Ledge Inc.  
Project: 107-21338

Job ID: 380-131110-1

**Job ID: 380-131110-1**

**Eurofins Eaton Analytical Pomona**

## Job Narrative 380-131110-1

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers and/or narrative comments are included to explain any exceptions, if applicable.

- Matrix QC may not be reported if insufficient sample is provided or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

### Receipt

The sample was received on 1/16/2025 10:10 AM. Unless otherwise noted below, the sample arrived in good condition, and, where required, properly preserved and on ice. The temperatures of the 4 coolers at receipt time were 10.4°C, 10.8°C, 12.7°C and 12.8°C.

### Subcontract Work

Method Asbestos: This method was subcontracted to Eurofins CEI Inc. The subcontract laboratory certification is different from that of the facility issuing the final report. The subcontract report is appended in its entirety.

### GC/MS VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### GC/MS Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### GC Semi VOA

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Herbicides

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Pesticides/PCBs

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### HPLC/IC

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Pesticides

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### LCMS

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Dioxin

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Metals

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### General Chemistry

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Gas Flow Proportional Counter

Method 903.0: Radium-226 batch 700102: Based upon client request, Ra-226 is reported without a 21-day waiting period to ensure

Eurofins Eaton Analytical Pomona

# Case Narrative

Client: Fox Ledge Inc.  
Project: 107-21338

Job ID: 380-131110-1

## Job ID: 380-131110-1 (Continued)

## Eurofins Eaton Analytical Pomona

short-lived alpha-emitting radium isotopes (e.g. Ra-224) have decayed out. The Ra-226 result should be considered to be potentially high biased. 107-21338 Spring Finished Product (380-131110-1), (LCS 160-700102/2-A), (MB 160-700102/1-A), (380-131053-A-1-A) and (380-131053-C-1-A DU)

Method 904.0: Radium 228 batch 700550: The laboratory control sample (LCS) recovery is outside the upper QC limit indicating a potential positive bias for that analyte. This analyte was not observed above the MDC/RL in the associated samples; therefore the sample data is not adversely affected by this excursion. The data have been reported with this narrative. (LCS 160-700550/2-A)

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

### Rad

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

# Sample Summary

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

---

Lab Sample ID	Client Sample ID	Matrix	Collected	Received	PWSID Number
380-131110-1	107-21338 Spring Finished Product	Bottled Water	01/14/25 07:23	01/16/25 10:10	2646395

---

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9

# Client Sample Results

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

Date Collected: 01/14/25 07:23

Matrix: Bottled Water

Date Received: 01/16/25 10:10

PWSID Number: 2646395

**Method: 524.2 - Total Trihalomethanes**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Trihalomethanes, Total	ND		0.50		ug/L		02/01/25 04:36	1	KP

**Method: 524.2 - Volatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
1,1,1,2-Tetrachloroethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,1,1-Trichloroethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,1,2,2-Tetrachloroethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,1,2-Trichloroethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,1-Dichloroethylene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,1-Dichloroethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,1-Dichloropropene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,2,3-Trichlorobenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,2,3-Trichloropropane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,2,4-Trichlorobenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,2,4-Trimethylbenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,2-Dichloroethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,2-Dichloroethene, Total	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,2-Dichloropropane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,3,5-Trimethylbenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
1,3-Dichloropropane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
2,2-Dichloropropane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
2-Butanone (MEK)	ND		5.0		ug/L		02/01/25 04:36	1	N4CJ
Benzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Bromobenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Bromochloromethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Bromodichloromethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Bromoethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Bromoform	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Bromomethane (Methyl Bromide)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Carbon disulfide	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Carbon tetrachloride	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Chlorobenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Chloroethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Chloroform (Trichloromethane)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Chloromethane (methyl chloride)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
cis-1,2-Dichloroethylene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
cis-1,3-Dichloropropene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Dibromochloromethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Dibromomethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Dichlorodifluoromethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Dichloromethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Diisopropyl ether	ND		3.0		ug/L		02/01/25 04:36	1	N4CJ
Ethylbenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Hexachlorobutadiene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Isopropylbenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
m,p-Xylenes	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
m-Dichlorobenzene (1,3-DCB)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Methyl-tert-butyl Ether (MTBE)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Naphthalene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
n-Butylbenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ

Eurofins Eaton Analytical Pomona

# Client Sample Results

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

Date Collected: 01/14/25 07:23

Matrix: Bottled Water

Date Received: 01/16/25 10:10

PWSID Number: 2646395

**Method: 524.2 - Volatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
N-Propylbenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
o-Chlorotoluene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
o-Dichlorobenzene (1,2-DCB)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
o-Xylene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
p-Chlorotoluene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
p-Dichlorobenzene (1,4-DCB)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
p-Isopropyltoluene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
sec-Butylbenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Styrene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Tert-amyl methyl ether	ND		3.0		ug/L		02/01/25 04:36	1	N4CJ
Tert-butyl ethyl ether	ND		3.0		ug/L		02/01/25 04:36	1	N4CJ
tert-Butylbenzene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Tetrachloroethene (PCE)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Toluene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
trans-1,2-Dichloroethylene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
trans-1,3-Dichloropropene	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Trichloroethylene (TCE)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Trichlorofluoromethane (Freon 11)	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Trichlorotrifluoroethane	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ
Vinyl Chloride (VC)	ND		0.30		ug/L		02/01/25 04:36	1	N4CJ
Xylenes, Total	ND		0.50		ug/L		02/01/25 04:36	1	N4CJ

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
1,2-Dichloroethane-d4 (Surr)	100		70 - 130	02/01/25 04:36	1	N4CJ
4-Bromofluorobenzene (Surr)	98		70 - 130	02/01/25 04:36	1	N4CJ
Toluene-d8 (Surr)	99		70 - 130	02/01/25 04:36	1	N4CJ

**Method: 525.2 - Semivolatile Organic Compounds (GC/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
2,4'-DDD	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
2,4'-DDE	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
2,4'-DDT	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
2,4-Dinitrotoluene	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
2,6-Dinitrotoluene	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
4,4'-DDD	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
4,4'-DDE	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
4,4'-DDT	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Acenaphthene	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Acenaphthylene	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Acetochlor	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Alachlor (Alanex)	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Aldrin	ND		0.0098		ug/L		01/30/25 11:31	1	Q8LA
alpha-BHC	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
alpha-Chlordane	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Anthracene	ND		0.020		ug/L		01/30/25 11:31	1	Q8LA
Atrazine	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Benz(a)anthracene	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Benzo[a]pyrene	ND		0.020		ug/L		01/30/25 11:31	1	Q8LA
Benzo[b]fluoranthene	ND		0.020		ug/L		01/30/25 11:31	1	Q8LA
Benzo[g,h,i]perylene	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA

Eurofins Eaton Analytical Pomona

# Client Sample Results

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

Date Collected: 01/14/25 07:23

Matrix: Bottled Water

Date Received: 01/16/25 10:10

PWSID Number: 2646395

**Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Benzo[k]fluoranthene	ND		0.020		ug/L		01/30/25 11:31	1	Q8LA
beta-BHC	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Bis(2-ethylhexyl) phthalate	ND		0.59		ug/L		01/30/25 11:31	1	Q8LA
Bromacil	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Butachlor	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Butylbenzylphthalate	ND		0.49		ug/L		01/30/25 11:31	1	Q8LA
Caffeine	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Chlorobenzilate	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Chloroneb	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Chlorothalonil (Draconil, Bravo)	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Chlorpyrifos	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Chrysene	ND		0.020		ug/L		01/30/25 11:31	1	Q8LA
delta-BHC	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Di(2-ethylhexyl)adipate	ND		0.59		ug/L		01/30/25 11:31	1	Q8LA
Dibenz(a,h)anthracene	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Diclorvos (DDVP)	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Dieldrin	ND		0.0098		ug/L		01/30/25 11:31	1	Q8LA
Diethylphthalate	ND		0.49		ug/L		01/30/25 11:31	1	Q8LA
Dimethoate	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Dimethylphthalate	ND		0.49		ug/L		01/30/25 11:31	1	Q8LA
Di-n-butyl phthalate	ND		0.98		ug/L		01/30/25 11:31	1	Q8LA
Di-n-octyl phthalate	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Endosulfan I (Alpha)	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Endosulfan II (Beta)	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Endosulfan sulfate	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Endrin	ND		0.0098		ug/L		01/30/25 11:31	1	Q8LA
Endrin aldehyde	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
EPTC	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Fluoranthene	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Fluorene	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
gamma-Chlordane	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Heptachlor	ND		0.0098		ug/L		01/30/25 11:31	1	Q8LA
Heptachlor epoxide (isomer B)	ND		0.0098		ug/L		01/30/25 11:31	1	Q8LA
Hexachlorobenzene	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Hexachlorocyclopentadiene	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Indeno[1,2,3-cd]pyrene	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Isophorone	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Lindane	ND		0.0098		ug/L		01/30/25 22:24	1	UPAC
Malathion	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Methoxychlor	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Metolachlor	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Metribuzin	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Molinate	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Naphthalene	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Parathion	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Pendimethalin (Penoxaline)	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Phenanthrene	ND		0.039		ug/L		01/30/25 11:31	1	Q8LA
Propachlor	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Pyrene	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA

Eurofins Eaton Analytical Pomona

# Client Sample Results

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

Date Collected: 01/14/25 07:23

Matrix: Bottled Water

Date Received: 01/16/25 10:10

PWSID Number: 2646395

## Method: 525.2 - Semivolatile Organic Compounds (GC/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Simazine	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Terbacil	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Terbutylazine	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
Thiobencarb	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA
trans-Nonachlor	ND		0.049		ug/L		01/30/25 11:31	1	Q8LA
Trifluralin	ND		0.098		ug/L		01/30/25 11:31	1	Q8LA

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
2-Nitro-m-xylene	99		70 - 130	01/30/25 11:31	1	Q8LA
2-Nitro-m-xylene	97		70 - 130	01/30/25 22:24	1	UPAC
Perylene-d12	83		70 - 130	01/30/25 11:31	1	Q8LA
Perylene-d12	97		70 - 130	01/30/25 22:24	1	UPAC
Triphenylphosphate	119		70 - 130	01/30/25 11:31	1	Q8LA
Triphenylphosphate	111		70 - 130	01/30/25 22:24	1	UPAC

## Method: 548.1 - Endothall (GC/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Endothall	ND		5.0		ug/L		01/29/25 09:54	1	X8AA

## Method: 504.1 - EDB, DBCP and 1,2,3-TCP (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
1,2,3-Trichloropropane	ND		0.020		ug/L		01/25/25 14:00	1	LZ8Q
1,2-Dibromo-3-Chloropropane	ND		0.010		ug/L		01/25/25 14:00	1	LZ8Q
1,2-Dibromoethane	ND		0.010		ug/L		01/25/25 14:00	1	LZ8Q

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
1,2-Dibromopropane (Surr)	108		60 - 140	01/25/25 14:00	1	LZ8Q

## Method: 505 - Organochlorine Pesticides/PCBs (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Chlordane	ND		0.10		ug/L		01/24/25 00:40	1	DR5R
PCB-1016	ND		0.072		ug/L		01/24/25 00:40	1	DR5R
PCB-1221	ND		0.10		ug/L		01/24/25 00:40	1	DR5R
PCB-1232	ND		0.10		ug/L		01/24/25 00:40	1	DR5R
PCB-1242	ND		0.10		ug/L		01/24/25 00:40	1	DR5R
PCB-1248	ND		0.10		ug/L		01/24/25 00:40	1	DR5R
PCB-1254	ND		0.10		ug/L		01/24/25 00:40	1	DR5R
PCB-1260	ND		0.072		ug/L		01/24/25 00:40	1	DR5R
Polychlorinated biphenyls, Total	ND		0.10		ug/L		01/24/25 00:40	1	DR5R
Toxaphene	ND		0.52		ug/L		01/24/25 00:40	1	DR5R

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
Tetrachloro-m-xylene	97		70 - 130	01/24/25 00:40	1	DR5R

## Method: 515.4 - Herbicides (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
2,4,5-T	ND		0.20		ug/L		01/31/25 01:40	1	K9GY
2,4,5-TP (Silvex)	ND		0.10		ug/L		01/31/25 01:40	1	K9GY
2,4-D	ND		0.10		ug/L		01/31/25 01:40	1	K9GY
2,4-DB	ND		2.0		ug/L		01/31/25 01:40	1	K9GY
3,5-Dichlorobenzoic acid	ND		0.50		ug/L		01/31/25 01:40	1	K9GY

Eurofins Eaton Analytical Pomona

# Client Sample Results

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

Date Collected: 01/14/25 07:23

Matrix: Bottled Water

Date Received: 01/16/25 10:10

PWSID Number: 2646395

## Method: 515.4 - Herbicides (GC) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Acifluorfen	ND		0.20		ug/L		01/31/25 01:40	1	K9GY
Bentazon	ND		0.50		ug/L		01/31/25 01:40	1	K9GY
Dalapon	ND		1.0		ug/L		01/31/25 01:40	1	K9GY
Dicamba	ND		0.10		ug/L		01/31/25 01:40	1	K9GY
Dichlorprop	ND		0.50		ug/L		01/31/25 01:40	1	K9GY
Dinoseb	ND		0.20		ug/L		01/31/25 01:40	1	K9GY
Pentachlorophenol	ND		0.040		ug/L		01/31/25 01:40	1	K9GY
Picloram	ND		0.10		ug/L		01/31/25 01:40	1	K9GY

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
2,4-Dichlorophenylacetic acid (Surr)	102		70 - 130	01/31/25 01:40	1	K9GY

## Method: 6251B - Haloacetic Acids (HAAs) (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Bromochloroacetic acid	ND		1.0		ug/L		01/25/25 03:15	1	KF9K
Dibromoacetic acid	ND		1.0		ug/L		01/25/25 03:15	1	KF9K
Dichloroacetic acid	ND		1.0		ug/L		01/25/25 03:15	1	KF9K
Monobromoacetic acid	ND		1.0		ug/L		01/25/25 03:15	1	KF9K
Monochloroacetic acid	ND		2.0		ug/L		01/25/25 03:15	1	KF9K
Trichloroacetic acid	ND		1.0		ug/L		01/25/25 03:15	1	KF9K

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
2,3-Dibromopropionic acid	107		70 - 130	01/25/25 03:15	1	KF9K

## Method: 6251B - Total Haloacetic Acids (GC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Total Haloacetic Acids 5	ND		2.0		ug/L		01/25/25 03:15	1	YXX2

## Method: 300.0 - Anions, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Chloride	1.3		0.50		mg/L		01/20/25 21:38	1	DXD4
Chlorite	ND		10		ug/L		01/23/25 08:52	1	UNJR
Nitrate as N	0.78		0.050		mg/L		01/20/25 21:38	1	DXD4
Bromide	7.9		5.0		ug/L		01/23/25 08:52	1	UNJR
Nitrite as N	ND		0.050		mg/L		01/20/25 21:38	1	DXD4
Sulfate	4.2		0.25		mg/L		01/20/25 21:38	1	DXD4

## Method: 300.0 - Nitrogen, Nitrate-Nitrite

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Nitrate Nitrite as N	0.78		0.050		mg/L		01/20/25 21:38	1	C4WQ

## Method: 317 - Bromate, Ion Chromatography

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Bromate	1.2		1.0		ug/L		01/28/25 04:48	1	XLG4

## Method: 531.2 - Carbamate Pesticides (HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
3-Hydroxycarbofuran	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM
Aldicarb	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM
Aldicarb sulfone	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM
Aldicarb sulfoxide	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM

Eurofins Eaton Analytical Pomona

# Client Sample Results

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

Date Collected: 01/14/25 07:23

Matrix: Bottled Water

Date Received: 01/16/25 10:10

PWSID Number: 2646395

### Method: 531.2 - Carbamate Pesticides (HPLC) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Baygon	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM
Carbaryl	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM
Carbofuran	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM
Methiocarb	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM
Methomyl	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM
Oxamyl	ND		0.50		ug/L		02/01/25 15:37	1	Q6XM

Surrogate	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
BDMC	97		70 - 130	02/01/25 15:37	1	Q6XM

### Method: 547 - Glyphosate (DAI HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Glyphosate	ND		6.0		ug/L		01/28/25 14:28	1	UD4M

### Method: 549.2 - Diquat and Paraquat (HPLC)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Diquat	ND		0.40		ug/L		01/27/25 15:26	1	UD4M
Paraquat	ND		2.0		ug/L		01/27/25 15:26	1	UD4M

### Method: 331.0 - Perchlorate (LC/MS/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Perchlorate	ND		0.50		ug/L		01/21/25 19:24	1	R6YA

### Method: 1613B - Tetra Chlorinated Dioxin (GC/MS/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
2,3,7,8-TCDD	ND		4.9		pg/L		01/24/25 17:34	1	X8AA

Isotope Dilution	%Recovery	Qualifier	Limits	Analyzed	Dil Fac	Analyst
<sup>13</sup> C-2,3,7,8-TCDD	72		31 - 137	01/24/25 17:34	1	X8AA

### Method: 200.7 - Metals (ICP)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Boron	ND		0.050		mg/L		01/22/25 14:27	1	MF7S
Calcium	12		0.10		mg/L		01/22/25 14:27	1	MF7S
Iron	ND		0.010		mg/L		01/22/25 14:27	1	MF7S
Magnesium	0.89		0.10		mg/L		01/22/25 14:27	1	MF7S
Potassium	0.41		0.10		mg/L		01/22/25 14:27	1	MF7S
Sodium	1.9		0.10		mg/L		01/22/25 14:27	1	MF7S

### Method: 200.8 - Mercury (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Hg	ND		0.20		ug/L		01/22/25 14:25	1	VB9B

### Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Aluminum	ND		20		ug/L		01/22/25 14:25	1	VB9B
Antimony	ND		2.0		ug/L		01/22/25 14:25	1	VB9B
Arsenic	ND		2.0		ug/L		01/22/25 14:25	1	VB9B
Barium	26		2.0		ug/L		01/22/25 14:25	1	VB9B
Beryllium	ND		0.30		ug/L		01/22/25 14:25	1	VB9B
Cadmium	ND		0.50		ug/L		01/22/25 14:25	1	VB9B
Chromium	ND		0.90		ug/L		01/22/25 14:25	1	VB9B

Eurofins Eaton Analytical Pomona

# Client Sample Results

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

Date Collected: 01/14/25 07:23

Matrix: Bottled Water

Date Received: 01/16/25 10:10

PWSID Number: 2646395

## Method: 200.8 - Metals (ICP/MS) (Continued)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	2.0		1.0		ug/L		01/22/25 14:25	1	VB9B
Lead	ND		0.50		ug/L		01/22/25 14:25	1	VB9B
Manganese	ND		2.0		ug/L		01/22/25 14:25	1	VB9B
Nickel	ND		1.0		ug/L		01/22/25 14:25	1	VB9B
Selenium	ND		2.0		ug/L		01/22/25 14:25	1	VB9B
Silver	ND		0.50		ug/L		01/22/25 14:25	1	VB9B
Thallium	ND		0.30		ug/L		01/22/25 14:25	1	VB9B
Uranium	ND		1.0		ug/L		01/22/25 14:25	1	VB9B
Zinc	ND		20		ug/L		01/22/25 14:25	1	VB9B
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Uranium	ND		0.67		pCi/L		01/22/25 14:25	1	VB9B

## Method: SM 2340B - Total Hardness (as CaCO3) by calculation

Analyte	Result	Qualifier	RL	RL	Unit	D	Analyzed	Dil Fac	Analyst
Hardness (as CaCO3)	34		2.9		mg/L		01/24/25 02:01	1	D5TU
Calcium hardness as CaCO3	30		2.5		mg/L		01/24/25 02:01	1	D5TU
Magnesium hardness as calcium carbonate	3.7		0.41		mg/L		01/24/25 02:01	1	D5TU

## General Chemistry

Analyte	Result	Qualifier	NONE	NONE	Unit	D	Analyzed	Dil Fac	Analyst
Corrosivity (SM 2330B)	-2.2				LangSU		01/20/25 17:29	1	UWAH
Langelier Index (SM 2330B)	-2.2				LangSU		01/20/25 17:29	1	UWAH
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Turbidity (180.1)	0.10		0.10		NTU		01/21/25 09:42	1	MQP5
Phenols, Total (420.4)	ND		1.0		ug/L		01/28/25 18:34	1	LQ3M
Cyanide (4500 CN F)	ND		0.025		mg/L		01/27/25 09:09	1	MQP5
Alkalinity as CaCO3 (SM 2320B)	31		2.0		mg/L		01/24/25 21:21	1	PK4Q
Bicarbonate Alkalinity as CaCO3 (SM 2320B)	31		2.0		mg/L		01/24/25 21:21	1	PK4Q
Carbonate Alkalinity as CaCO3 (SM 2320B)	ND		2.0		mg/L		01/24/25 21:21	1	PK4Q
Hydroxide Alkalinity as CaCO3 (SM 2320B)	ND		2.0		mg/L		01/24/25 21:21	1	PK4Q
Specific Conductance (SM 2510B)	79		2.0		umhos/cm		01/24/25 21:21	1	PK4Q
Total Dissolved Solids (SM 2540C)	44		10		mg/L		01/22/25 11:34	1	WZH3
Chlorine, Total Residual (SM 4500 Cl G)	ND		0.050		mg/L		01/30/25 16:37	1	V7DE
Chloramines, Total (SM 4500 Cl G)	ND		0.050		mg/L		01/30/25 16:37	1	V7DE
Chlorine, free (SM 4500 Cl G)	0.050		0.050		mg/L		01/30/25 16:37	1	V7DE
Fluoride (SM 4500 F C)	ND		0.050		mg/L		01/25/25 01:21	1	PK4Q
Methylene Blue Active Substances (SM 5540C)	ND		0.10		mg/L		01/23/25 17:58	1	DN4H
Analyte	Result	Qualifier	RL	RL	Unit	D	Analyzed	Dil Fac	Analyst
Chlorine dioxide (4500 ClO2 D)	ND		0.24		mg/L		01/30/25 16:37	1	V7DE
Color, Apparent (SM 2120B)	3.0		2.0		Color Units		01/20/25 19:29	1	QDP7
Odor (SM 2150B)	ND		1.0		T.O.N.		01/20/25 17:02	1	QDP7
pH (SM 4500 H+ B)	6.5	HF	0.01		SU		01/21/25 16:09	1	DN4H

# Client Sample Results

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

Date Collected: 01/14/25 07:23

Matrix: Bottled Water

Date Received: 01/16/25 10:10

PWSID Number: 2646395

## Method: 900.0 - Gross Alpha and Gross Beta Radioactivity

Analyte	Result	Qualifier	Count	Total	RL	MDC	Unit	Analyzed	Dil Fac	Analyst
			Uncert. (2σ+/-)	Uncert. (2σ+/-)						
Gross Alpha	0.460	U	0.524	0.526	3.00	0.529	pCi/L	01/26/25 13:26	1	MLS
Gross Beta	0.977		0.707	0.714	4.00	0.651	pCi/L	01/26/25 13:26	1	MLS

## Method: 903.0 - Radium-226 (GFPC)

Analyte	Result	Qualifier	Count	Total	RL	MDC	Unit	Analyzed	Dil Fac	Analyst
			Uncert. (2σ+/-)	Uncert. (2σ+/-)						
Radium-226	0.0679	U	0.249	0.249	1.00	0.311	pCi/L	01/31/25 08:04	1	FLC
<b>Carrier</b>	<b>%Yield</b>	<b>Qualifier</b>	<b>Limits</b>					<b>Analyzed</b>	<b>Dil Fac</b>	<b>Analyst</b>
Ba Carrier	75.8		30 - 110					01/31/25 08:04	1	FLC

## Method: 904.0 - Radium-228 (GFPC)

Analyte	Result	Qualifier	Count	Total	RL	MDC	Unit	Analyzed	Dil Fac	Analyst
			Uncert. (2σ+/-)	Uncert. (2σ+/-)						
Radium-228	0.0382	U *	0.313	0.313	1.00	0.357	pCi/L	02/06/25 12:53	1	SWS
<b>Carrier</b>	<b>%Yield</b>	<b>Qualifier</b>	<b>Limits</b>					<b>Analyzed</b>	<b>Dil Fac</b>	<b>Analyst</b>
Ba Carrier	79.3		30 - 110					02/06/25 12:53	1	SWS
Y Carrier	81.1		30 - 110					02/06/25 12:53	1	SWS

## Method: Ra226\_Ra228 Pos - Combined Radium-226 and Radium-228

Analyte	Result	Qualifier	Count	Total	RL	MDC	Unit	Analyzed	Dil Fac	Analyst
			Uncert. (2σ+/-)	Uncert. (2σ+/-)						
Combined Radium 226 + 228	0.106	U	0.400	0.400	5.00	0.357	pCi/L	02/06/25 11:20	1	CAH

# Action Limit Summary

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**

**Lab Sample ID: 380-131110-1**

**PWSID Number: 2646395**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	EPAMCLS Limit	RL	Method	Prep Type
Trihalomethanes, Total	ND		ug/L	80		0.50	524.2	Total/NA
1,1,1-Trichloroethane	ND		ug/L	200		0.50	524.2	Total/NA
1,1,2-Trichloroethane	ND		ug/L	5		0.50	524.2	Total/NA
1,1-Dichloroethylene	ND		ug/L	7		0.50	524.2	Total/NA
1,2,4-Trichlorobenzene	ND		ug/L	70		0.50	524.2	Total/NA
1,2-Dichloroethane	ND		ug/L	5		0.50	524.2	Total/NA
1,2-Dichloropropane	ND		ug/L	5		0.50	524.2	Total/NA
Benzene	ND		ug/L	5		0.50	524.2	Total/NA
Carbon tetrachloride	ND		ug/L	5		0.50	524.2	Total/NA
Chlorobenzene	ND		ug/L	100		0.50	524.2	Total/NA
cis-1,2-Dichloroethylene	ND		ug/L	70		0.50	524.2	Total/NA
Dichloromethane	ND		ug/L	5		0.50	524.2	Total/NA
Ethylbenzene	ND		ug/L	700		0.50	524.2	Total/NA
o-Dichlorobenzene (1,2-DCB)	ND		ug/L	600		0.50	524.2	Total/NA
p-Dichlorobenzene (1,4-DCB)	ND		ug/L	75		0.50	524.2	Total/NA
Styrene	ND		ug/L	100		0.50	524.2	Total/NA
Tetrachloroethene (PCE)	ND		ug/L	5		0.50	524.2	Total/NA
Toluene	ND		ug/L	1000		0.50	524.2	Total/NA
trans-1,2-Dichloroethylene	ND		ug/L	100		0.50	524.2	Total/NA
Trichloroethylene (TCE)	ND		ug/L	5		0.50	524.2	Total/NA
Vinyl Chloride (VC)	ND		ug/L	2		0.30	524.2	Total/NA
Xylenes, Total	ND		ug/L	10000		0.50	524.2	Total/NA
Alachlor (Alanex)	ND		ug/L	2		0.049	525.2	Total/NA
Atrazine	ND		ug/L	3		0.049	525.2	Total/NA
Benzo[a]pyrene	ND		ug/L	0.2		0.020	525.2	Total/NA
Bis(2-ethylhexyl) phthalate	ND		ug/L	6		0.59	525.2	Total/NA
Di(2-ethylhexyl)adipate	ND		ug/L	400		0.59	525.2	Total/NA
Endrin	ND		ug/L	2		0.0098	525.2	Total/NA
Heptachlor	ND		ug/L	0.4		0.0098	525.2	Total/NA
Heptachlor epoxide (isomer B)	ND		ug/L	0.2		0.0098	525.2	Total/NA
Hexachlorobenzene	ND		ug/L	1		0.049	525.2	Total/NA
Hexachlorocyclopentadiene	ND		ug/L	50		0.049	525.2	Total/NA
Lindane	ND		ug/L	0.2		0.0098	525.2	Total/NA
Methoxychlor	ND		ug/L	40		0.049	525.2	Total/NA
Simazine	ND		ug/L	4		0.049	525.2	Total/NA
Endothall	ND		ug/L	100		5.0	548.1	Total/NA
1,2-Dibromo-3-Chloropropane	ND		ug/L	0.2		0.010	504.1	Total/NA
1,2-Dibromoethane	ND		ug/L	0.05		0.010	504.1	Total/NA
Chlordane	ND		ug/L	2		0.10	505	Total/NA
Polychlorinated biphenyls, Total	ND		ug/L	0.5		0.10	505	Total/NA
Toxaphene	ND		ug/L	3		0.52	505	Total/NA
2,4,5-TP (Silvex)	ND		ug/L	50		0.10	515.4	Total/NA
2,4-D	ND		ug/L	70		0.10	515.4	Total/NA
Dalapon	ND		ug/L	200		1.0	515.4	Total/NA
Dinoseb	ND		ug/L	7		0.20	515.4	Total/NA
Pentachlorophenol	ND		ug/L	1		0.040	515.4	Total/NA
Picloram	ND		ug/L	500		0.10	515.4	Total/NA

Eurofins Eaton Analytical Pomona

# Action Limit Summary

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product**  
**(Continued)**

**Lab Sample ID: 380-131110-1**

**PWSID Number: 2646395**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	EPAMCLS Limit	RL	Method	Prep Type
Total Haloacetic Acids 5	ND		ug/L	60		2.0	6251B	Total/NA
Chloride	1.3		mg/L		250	0.50	300.0	Total/NA
Chlorite	ND		ug/L	1000		10	300.0	Total/NA
Nitrate as N	0.78		mg/L	10		0.050	300.0	Total/NA
Nitrite as N	ND		mg/L	1		0.050	300.0	Total/NA
Sulfate	4.2		mg/L		250	0.25	300.0	Total/NA
Nitrate Nitrite as N	0.78		mg/L	10		0.050	300.0	Total/NA
Bromate	1.2		ug/L	10		1.0	317	Total/NA
Aldicarb	ND		ug/L	3		0.50	531.2	Total/NA
Aldicarb sulfone	ND		ug/L	2		0.50	531.2	Total/NA
Aldicarb sulfoxide	ND		ug/L	4		0.50	531.2	Total/NA
Carbofuran	ND		ug/L	40		0.50	531.2	Total/NA
Oxamyl	ND		ug/L	200		0.50	531.2	Total/NA
Glyphosate	ND		ug/L	700		6.0	547	Total/NA
Diquat	ND		ug/L	20		0.40	549.2	Total/NA
2,3,7,8-TCDD	ND		pg/L	30		4.9	1613B	Total/NA
Iron	ND		mg/L		0.3	0.010	200.7	Total/NA
Hg	ND		ug/L	2		0.20	200.8	Total/NA
Aluminum	ND		ug/L		50	20	200.8	Total/NA
Antimony	ND		ug/L	6		2.0	200.8	Total/NA
Arsenic	ND		ug/L	10		2.0	200.8	Total/NA
Barium	26		ug/L	2000		2.0	200.8	Total/NA
Beryllium	ND		ug/L	4		0.30	200.8	Total/NA
Cadmium	ND		ug/L	5		0.50	200.8	Total/NA
Chromium	ND		ug/L	100		0.90	200.8	Total/NA
Copper	2.0		ug/L		1000	1.0	200.8	Total/NA
Lead	ND		ug/L	15.000		0.50	200.8	Total/NA
Manganese	ND		ug/L		50	2.0	200.8	Total/NA
Selenium	ND		ug/L	50		2.0	200.8	Total/NA
Silver	ND		ug/L		100	0.50	200.8	Total/NA
Thallium	ND		ug/L	2		0.30	200.8	Total/NA
Uranium	ND		ug/L	30		1.0	200.8	Total/NA
Uranium	ND		pCi/L	20		0.67	200.8	Total/NA
Zinc	ND		ug/L		5000	20	200.8	Total/NA
Chlorine dioxide	ND		mg/L	0.8		0.24	4500 ClO2 D	Total/NA
Cyanide	ND		mg/L	0.2		0.025	4500 CN F	Total/NA
Color, Apparent	3.0		Color Units		15	2.0	SM 2120B	Total/NA
Odor	ND		T.O.N.		3	1.0	SM 2150B	Total/NA
Total Dissolved Solids	44		mg/L		500	10	SM 2540C	Total/NA
Chlorine, Total Residual	ND		mg/L	4		0.050	SM 4500 Cl G	Total/NA
Fluoride	ND		mg/L	4	2	0.050	SM 4500 F C	Total/NA
pH	6.5	HF	SU		6.5	0.01	SM 4500 H+ B	Total/NA
Methylene Blue Active Substances	ND		mg/L		0.5	0.10	SM 5540C	Total/NA
Gross Alpha	0.460	U	pCi/L	15		3.00	900.0	Total/NA
Gross Beta	0.977		pCi/L	50		4.00	900.0	Total/NA

# Action Limit Summary

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

**Client Sample ID: 107-21338 Spring Finished Product  
(Continued)**  
**PWSID Number: 2646395**

**Lab Sample ID: 380-131110-1**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	EPAMCL Limit	EPAMCLS Limit	RL	Method	Prep Type
Combined Radium 226 + 228	0.106	U	pCi/L	5		5.00	Ra226_Ra228 Pos	Total/NA

# Accreditation/Certification and Definitions Summary

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

## Laboratory: Eurofins Eaton Analytical Pomona

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
A2LA	ISO/IEC 17025	5890.01 & 5890.02	06-30-25
Alabama	State	41060	06-18-25
Arizona	State	AZ0833	02-26-25
Arkansas (DW)	State	CA00006	01-31-25 *
California	State	2813	06-18-25
Colorado	State	CA00006	01-31-26
Connecticut	State	PH-0107	03-31-26
Delaware (DW)	State	CA00006	01-31-26
Florida	NELAP	E871024	06-30-25
Georgia (DW)	State	947	01-31-25 *
Guam	State	24-03R	03-31-25
Hawaii	State	CA00006	01-31-25 *
Hawaii (Micro)	State	CA00006	01-31-25 *
Idaho (DW)	State	CA00006	01-31-25 *
Idaho (Micro)	State	CA00006	03-31-25
Illinois	NELAP	200033	03-31-25
Indiana	State	C-CA-01	06-18-25
Kansas	NELAP	E-10268	04-30-25
Kentucky (DW)	State	KY90107	12-31-25
Louisiana (DW)	State	LA008	12-31-25
Maine	State	CA00006A	03-08-26
Maryland	State	224	03-31-25
Massachusetts	State	M-CA006	06-30-25
MI - RadChem Recognition	State	9906	06-18-25
Michigan	State	9906	06-18-25
Mississippi	State	CA2813	06-18-25
Montana (DW)	State	CERT0035	01-01-26
Nebraska	State	NE-OS-21-13	01-31-25 *
Nevada	State	CA00006	07-31-25
New Hampshire	NELAP	2959	03-29-25
New Jersey	NELAP	CA008	06-30-25
New Mexico	State	CA00006	01-31-26
New York	NELAP	11320	04-01-25
North Carolina (DW)	State	06701	07-31-25
North Dakota	State	R-009	01-31-24 *
Northern Mariana Islands (DW)	State	CA00006	01-31-25 *
Ohio	State	87786	01-31-25 *
Oregon	NELAP	4034	01-29-26
Pennsylvania	NELAP	68-00565	10-31-25
Puerto Rico	State	CA00006	03-31-25
Rhode Island	State	LAO00381	12-30-25
South Dakota (DW)	State	CA11320	06-18-25
Tennessee	State	TN02839	01-31-25 *
Texas	NELAP	T104704230	09-30-25
USEPA UCMR 5	US Federal Programs	CA00006	12-31-25
Utah	NELAP	CA00006	01-31-25 *
Vermont	State	VT-0114	12-28-25
Virginia	NELAP	460260	06-14-25
Washington	State	C838	03-13-25
Wyoming	State	8-TMS-L	06-18-25

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Eurofins Eaton Analytical Pomona

# Accreditation/Certification and Definitions Summary

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

## Laboratory: Eurofins St. Louis

All accreditations/certifications held by this laboratory are listed. Not all accreditations/certifications are applicable to this report.

Authority	Program	Identification Number	Expiration Date
Alaska (UST)	State	20-001	05-06-25
ANAB	Dept. of Defense ELAP	L2305	04-06-25
ANAB	Dept. of Energy	L2305.01	04-06-25
ANAB	ISO/IEC 17025	L2305	04-06-25
Arizona	State	AZ0813	12-08-25
California	Los Angeles County Sanitation Districts	10259	06-30-22 *
California	State	2886	06-30-25
Connecticut	State	PH-0241	03-31-25
Florida	NELAP	E87689	06-30-25
HI - RadChem Recognition	State	n/a	06-30-25
Illinois	NELAP	200023	11-30-25
Iowa	State	373	12-01-26
Kansas	NELAP	E-10236	10-31-25
Kentucky (DW)	State	KY90125	12-31-25
Kentucky (WW)	State	KY90125 (Permit KY0004049)	12-31-25
Louisiana	NELAP	04080	06-30-22 *
Louisiana (All)	NELAP	04080	06-30-25
Louisiana (DW)	State	LA011	12-31-25
Maryland	State	310	09-30-25
Massachusetts	State	M-MO054	06-30-25
MI - RadChem Recognition	State	9005	06-30-25
Missouri	State	780	06-30-25
Nevada	State	MO00054	07-31-25
New Jersey	NELAP	MO002	06-30-25
New Mexico	State	MO00054	06-30-25
New York	NELAP	11616	03-31-25
North Carolina (DW)	State	29700	07-31-25
North Dakota	State	R-207	06-30-24 *
Oklahoma	NELAP	9997	08-31-25
Oregon	NELAP	4157	09-01-25
Pennsylvania	NELAP	68-00540	02-28-25
South Carolina	State	85002001	06-30-25
Texas	NELAP	T104704193	07-31-25
US Fish & Wildlife	US Federal Programs	058448	07-31-25
USDA	US Federal Programs	P330-17-00028	05-18-26
Utah	NELAP	MO00054	07-31-25
Virginia	NELAP	460230	06-14-25
Washington	State	C592	08-30-25
West Virginia DEP	State	381	10-31-25

## Qualifiers

### General Chemistry

Qualifier	Qualifier Description
HF	Parameter with a holding time of 15 minutes. Test performed by laboratory at client's request. Sample was analyzed outside of hold time.

### Rad

Qualifier	Qualifier Description
*	LCS or LCSD is outside acceptance limits.

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

Eurofins Eaton Analytical Pomona

# Accreditation/Certification and Definitions Summary

Client: Fox Ledge Inc.  
Project/Site: 107-21338

Job ID: 380-131110-1  
SDG: Fox Ledge - Honesdale - Spring Finished Product

## Qualifiers (Continued)

### Rad (Continued)

Qualifier	Qualifier Description
U	Result is less than the sample detection limit.

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
MRL	Method Reporting Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
SDL	Sample Detection Limit
SDL	Sample Detection Limit
SDL	Sample Detection Limit
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

\* Accreditation/Certification renewal pending - accreditation/certification considered valid.

January 30, 2025

Rachelle Arada  
Eurofins Eaton Analytical (Pomona)  
941 Corporate Center Drive  
Pomona, CA 91768

**CLIENT PROJECT:** 107-21338, 38008392, 380-131110-1  
**LAB CODE:** 630092-1


Dear Rachelle,

Enclosed are asbestos analysis results for TEM water samples received at our laboratory on January 23, 2025. The samples were analyzed for asbestos using transmission electron microscopy (TEM) per the US EPA 100.2 Method.

The current EPA regulatory limit for asbestos in water is 7 million fibers per liter (MFL, > 10  $\mu\text{m}$  in length). The analytical sensitivity for the EPA 100.2 method is 0.2 MFL.

Thank you for your business and we look forward to continuing good relations.

Kind Regards,



Tianbao Bai, Ph.D., CIH  
Laboratory Director

---

**ASBESTOS ANALYTICAL REPORT**  
**By: Transmission Electron Microscopy**

Prepared for

**Eurofins Eaton Analytical (Pomona)**

---

CLIENT PROJECT: 107-21338, 38008392, 380-131110-1

LAB CODE: 630092-1

TEST METHOD: EPA 100.2

REPORT DATE: 01/30/25



# ASBESTOS IN WATER ANALYSIS

By: Transmission Electron Microscopy

**Client:** Eurofins Eaton Analytical (Pomona)  
941 Corporate Center Drive  
Pomona, CA 91768

**Lab Code:** 630092-1  
**Date Received:** 01/23/25  
**Date Analyzed:** 01/30/25  
**Date Reported:** 01/30/25

**Project:** 107-21338, 38008392, 380-131110-1

**Method:** TEM EPA 100.2 (DRINKING WATER)

Client ID	Date Collected	Date Filtered	Sample Volume Filtered	Dilution Factor	Effective Filter Area (mm <sup>2</sup> )	# of Grids Openings Analyzed	Total Area Of Filter Examined	Analytical Sensitivity (MFL)	Asbestos Type	Concentration >10µm (MFL)	Confidence Limit Lower	Confidence Limit Upper
1007-21338	01/14/25	01/24/25	100	1	1060	6	0.06	0.177	None	0	0	<0.65
Spring Finished Product (380-131110-1)	07:23	14:56							Detected			
3005978												



---

**LEGEND:** MFL = million fibers per liter, > 10 µm in length

---

**METHOD:** EPA 100.2

---

**AVERAGE GRID OPENING SIZE:** 0.010 mm<sup>2</sup>

---

**ANALYTICAL SENSITIVITY:** 0.2 MFL

---

**MAXIMUM CONTAMINANT LEVEL:** 7 MFL

---

Eurofins Built Environment Testing East, LLC makes no warranty representation regarding the accuracy of client submitted information in preparing and presenting analytical results. Interpretation of the analytical results is the sole responsibility of the client. This report relates only to the samples tested or analyzed and may not be reproduced, except in full, without written approval by Eurofins Built Environment Testing East, LLC. Estimated measurement of uncertainty is available on request. Samples were received in acceptable condition unless otherwise noted.

Information provided by customer includes customer sample ID, location, volume and area as well as date and time of sampling.

Sample bottle was not provided by Eurofins Built Environment Testing East, LLC.

For the current states of certification please refer to the website: [www.eurofinsus.com/environment-testing/built-environment/locations/eurofins-cei/](http://www.eurofinsus.com/environment-testing/built-environment/locations/eurofins-cei/)




Partima Poudel Acharya  
Analyst

**DATA QA:**



Alyssa Thompson  
1/30/2025

**APPROVED BY:**



Tianbao Bai, Ph.D., CIH  
Laboratory Director



SUBMITTED BY	INVOICE TO	CONTACT INFORMATION	SERIES
Company: Eurofins Eaton Analytical (Pomona) Address: 941 Corporate Center Drive Pomona, CA 91768	Company: Eurofins Eaton Analytical (Pomona) Address: 941 Corporate Center Drive Pomona, CA 91768	Contact: Rachelle Arada Phone: (626) 386-1100 Fax: Cell:	-1 TEM Standard
Project Number and/or P.O. #: None Given Project Description/Location: 107-21338, 38008392, 380-131110-1	Project Zip Code:	Final Data Deliverable Email Address: rachelle.arada@et.eurofinsus.com (+ 2 ADDNL. CONTACTS)	

ASBESTOS LABORATORY	REQUESTED ANALYSIS						VALID MATRIX CODES			LAB NOTES
PLM / PCM / TEM DTL RUSH PRIORITY STANDARD							Air = A	Bulk = B	1.9C	
CHEMISTRY LABORATORY							Dust = D	Food = F		
Dust RUSH PRIORITY STANDARD							Paint = P	Soil = S		
Metals RUSH PRIORITY STANDARD *PRIOR NOTICE REQUIRED FOR SAME DAY TAT							Surface = SU	Swab = SW		
Organics* SAME DAY RUSH PRIORITY STANDARD							Tape = T	Wipe = W		
MICROBIOLOGY LABORATORY							Drinking Water = DW			
Medical Device Analysis RUSH STANDARD							Waste Water = WW			
Mold Analysis RUSH PRIORITY STANDARD							**ASTM E1792 approved wipe media only**			
Special Instructions:										
Client Sample ID Number (Sample ID's must be unique)	ASBESTOS	CHEMISTRY	MICROBIOLOGY	ICO						
1 1007-21338 Spring Finished Product (380-131110-1)	X					Sample Volume (L) / Area	DW	01/14/25	05:23	

Eurofins Built Environment Testing East, LLC establishes a unique Lab Sample ID, for each sample, by preceding each unique Client Sample ID with the laboratory RES Job Number. Eurofins Built Environment Testing East, LLC will analyze incoming samples based on information received and will not be responsible for errors or omissions in calculations resulting from the inaccuracy of original data. By signing, client/company representative agrees that submission of the following samples for requested analysis as indicated on this Chain of Custody shall constitute an analytical services agreement with payment terms of NET 30 days. Failure to comply with payment terms may result in a 1.5% monthly interest surcharge.

Relinquished By:	Date/Time: 01/23/2025 10:45:29	Sample Condition: Acceptable
Received By:	Alyssa Thompson Date/Time: 01/23/2025 12:58:07	Carrier: Fed-Ex

1  
2  
3  
4  
5  
6  
7  
8  
9

Eurofins Eaton Analytical Pomona  
 941 Corporate Center Drive  
 Pomona, CA 91768-2642  
 Phone: 626-386-1100

Chain of Custody Record

630092



W8254  
 eurofins | Environment Testing

**Client Information (Sub Contract Lab)**

Client Contact:	Lab P#:	Arada, Rachelle	Center Tracking Note:	GCC No:
Shipping/Receiving:	Phone:	Rachelle.Arada@eurofins.com	N/A	380-184294.1
Company:	Address:	Eurofins CEI Inc	State of Origin:	Page 1 of 1
730 SE Maynard Road,	City:		Pennsylvania	Job #:
Cary	State, Zip:	NC, 27511		380-131110-1
Phone:	TAT Requested (days):	N/A	Analysis Requested	Preservation Codes:
Project Name:	Project #:	38008392		
Site:	SSOW#:	N/A		
Other:				

Sample Identification - Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (G=grab)	Matrix (Water, Solid, Tissue, Ash)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	SUB (Asbestos)	Total Number of Containers	Special Instructions/Note:
107-21338 Spring Finished Product (380-131110-1)	1/14/25	07:23 Eastern	G	Bottled Water		X		1	See Attached Instructions 1.90C
<del>Accept Samples</del>									

**Possible Hazard Identification**

Unconfirmed Deliverable Requested: I, II, III, IV, Other (specify) \_\_\_\_\_ Primary Deliverable Rank: 1

Empty Kit Relinquished by: \_\_\_\_\_ Date: \_\_\_\_\_

Relinquished by: Colleno Date/Time: 1-21/25 -TAS Company: \_\_\_\_\_

Relinquished by: \_\_\_\_\_ Date/Time: \_\_\_\_\_ Company: \_\_\_\_\_

Relinquished by: \_\_\_\_\_ Date/Time: \_\_\_\_\_ Company: \_\_\_\_\_

Custody Seals Intact: Δ Yes Δ No Custody Seal No.: \_\_\_\_\_

Cooler Temperature(s) °C and Other Remarks: \_\_\_\_\_

Special Instructions/QC Requirements: \_\_\_\_\_

Return To Client  Disposal By Lab  Archive For \_\_\_\_\_ Months


Sample Disposal (A fee may be assessed if samples are retained longer than 1 month)

<b>Lab Name</b>	Eurofins Built Environment Testing East, LLC	<b>Client</b>	Eurofins Eaton Analytical (Pomona)	<b>Analyzed By</b>	PPA
<b>Primary Scope</b>	JEM-1200EX	<b>Sample Type</b>	Water	<b>Analysis Date</b>	01/30/2025
<b>Voltage</b>	100KV	<b>Vol/Area</b>		<b>Prep Method</b>	Indirect
<b>Magnification</b>	20000	<b>Lab Code</b>	630092-1	<b>Date Received</b>	01/23/2025
<b>Primary Filter Area (mm²)</b>		<b>Sec. Filter Area (mm²)</b>	1060	<b>Grid Opening Area (mm²)</b>	0.01
<b>Sample ID</b>	1007-21338 Spring Finished Product (380-131110-1)	<b>Method</b>	EPA 100.2	<b>Scope Align</b>	01/30/2025
<b>Suspension</b>		<b>Aliquot</b>	100	<b>Grid Openings</b>	6

Grid	GO	Type	Count	Total	Length	Width	ID	Mineral Class	Comments	Photo	EDS
2H20415											
A8	G5-6	ND									
	E5-6	ND									
2H20415											
A7	G5-4	ND									
	E4-1	ND									
2H20415											
A9	F5-1	ND									
	K5-4	ND									

# CHAIN OF CUSTODY RECORD

\*107-21338-13\*




<b>INVOICE TO/SEND ORIGINAL REPORT TO:</b> <b>Compliance Designs</b> 159 South Stark Highway Weare, New Hampshire 03281 Tel (603) 273-0954 Fax (603) 695-7318		<b>CLIENT NAME TO APPEAR ON REPORT:</b> Fox Ledge Inc. 1432 Bethany Turnpike Honesdale PA 18431		<b>LAB USED:</b> Eurofins - Pomona ORDER # 38008392 TURNAROUND TIME: STND/BUT ASAP PWS #: 2646395
<b>PROJECT NAME:</b> 2025 Annual		<b>PROJECT #:</b> 107		ANALYSIS REQUIRED
<b>SAMPLE NUMBER</b> 107-21338	<b>DATE &amp; TIME OF SAMPLE COLLECTION</b> 1/14/25 0723	<b>SAMPLE DESCRIPTION AND PRODUCTION CODE</b> Spring Finished Product		
<b>LAB, PLEASE INDICATE DATE AND TIME BOTTLES OPENED (SAMPLE DATE &amp; TIME)</b>		Produced From: Spring 1 Size: <u>1.5 liter</u> If multiple shipments indicate shipment <u>1</u> of <u>4</u>		 380-131110 COC
<b>SAMPLER'S SIGNATURE:</b> <i>Monica DelCualo</i>		PLEASE PRINT BELOW: Line: 1 PWS ID#: 100 Location: Spring FP COMPLIANCE CRITERIA:		
<b>RELINQUISHED BY</b> <i>Monica DelCualo</i>		<b>ACCEPTED BY</b> <i>Monica DelCualo</i>		<b>REPORT TO PA DEP</b>
<b>DATE/TIME</b> 1/14/25 0723		<b>DATE/TIME</b> 1/16/25 1010		<b>NOTES TO LABORATORY</b> (G31A) 1011 TO 13 = 10.4 UPS 1280FV981210416 6659 *PLEASE PUT PFAS ON A SEPARATE REPORT EGAR

Feb 2 2025 1/21/25 0930



# CHAIN OF CUSTODY RECORD

\*107-21338-13\*

<b>INVOICE TO/SEND ORIGINAL REPORT TO:</b> <b>Compliance</b> 159 South Stark Highway Weare, New Hampshire 03281 Tel (603) 273-0954 Fax (603) 695-7318		<b>CLIENT NAME TO APPEAR ON REPORT:</b> Fox Ledge Inc. 1432 Bethany Turnpike Honesdale PA 18431		<b>LAB USED:</b> Eurofins -Pomona ORDER # 38008392 TURNAROUND TIME: STND/BUT ASAP PWS #: 2646395
<b>PROJECT NAME:</b> 2025 Annual		<b>PROJECT #:</b> 107	<b>NUMBER OF CONTAINERS</b>	
<b>SAMPLE NUMBER</b> 107-21338	<b>DATE &amp; TIME OF SAMPLE COLLECTION</b> 1/14/25 0723	<b>SAMPLE DESCRIPTION AND PRODUCTION CODE</b> Spring Finished Product	ANALYSIS REQUIRED	
<b>LAB, PLEASE INDICATE DATE AND TIME BOTTLES OPENED (SAMPLE DATE &amp; TIME)</b>		Produced From: Spring 1 Size: 1.5 liter if multiple shipments indicate shipment 2 of 4	50-BAT1-FP, Plus PFAS (537.1)*	
<b>SAMPLER'S SIGNATURE:</b> 		PLEASE PRINT BELOW: MONICA DeLuca	COMPLIANCE CRITERIA: <b>REPORT TO PA DEP</b>	
<b>RELINQUISHED BY</b> 	<b>DATE/TIME</b> 1/14/25 0723	<b>ACCEPTED BY</b> 	<b>DATE/TIME</b> 1/16/25 1010	<b>NOTES TO LABORATORY</b> (631A) 10.5 + 0.3 = 10.8 No ice URS 1280F U9812 1342 0442 *PLEASE PUT PFAS ON A SEPARATE REPORT EGAR



# CHAIN OF CUSTODY RECORD




\*107-21338-13\*

<b>INVOICE TO/SEND ORIGINAL REPORT TO:</b> <b>Compliance</b> <b>Designs</b> 159 South Stark Highway Weare, New Hampshire 03281 Tel (603) 273-0954 Fax (603) 695-7318		<b>CLIENT NAME TO APPEAR ON REPORT:</b> Fox Ledge Inc. 1432 Bethany Turnpike Honesdale PA 18431		<b>LAB USED:</b> Eurofins -Pomona ORDER # 38008392 TURNAROUND TIME: STND/BUT ASAP PWS #: 2646395
<b>PROJECT NAME:</b> 2025 Annual		<b>PROJECT #:</b> 107	<b>NUMBER OF CONTAINERS</b>	
<b>SAMPLE NUMBER</b> 107-21338	<b>DATE &amp; TIME OF SAMPLE COLLECTION</b> 1/14/25 0723	<b>SAMPLE DESCRIPTION AND PRODUCTION CODE</b> Spring Finished Product	ANALYSIS REQUIRED	
<b>LAB, PLEASE INDICATE DATE AND TIME BOTTLES OPENED (SAMPLE DATE &amp; TIME)</b>		Produced From: Spring 1 Size: 1.5 liter If multiple shipments indicate shipment 2 of 7	50-BAT1-FP, Plus PFAS (537.1)*	
<b>SAMPLER'S SIGNATURE:</b> <i>Monica DelCorno</i>		PLEASE PRINT BELOW: MONICA DELCORN	COMPLIANCE CRITERIA: REPORT TO PA DEP	
<b>RELINQUISHED BY</b> <i>Monica DelCorno</i>	<b>DATE/TIME</b> 1-14-25 0723	<b>ACCEPTED BY</b> <i>Ryan Moran</i>	<b>DATE/TIME</b> 1-17-25 1006	<b>NOTES TO LABORATORY</b> Pack 1780F U9812 131316 08 *PLEASE PUT PFAS ON A SEPARATE REPORT 961A 12.5-10.3 17.80 V6 102



# CHAIN OF CUSTODY RECORD

\*107-21338-13\*

<b>INVOICE TO/SEND ORIGINAL REPORT TO:</b> <b>Compliance</b> 159 South Stark Highway Weare, New Hampshire 03281 <b>Designs</b> Tel (603) 273-0954 Fax (603) 695-7318		<b>CLIENT NAME TO APPEAR ON REPORT:</b> Fox Ledge Inc. 1432 Bethany Turnpike Honesdale PA 18431		<b>LAB USED:</b> Eurofins -Pomona ORDER # 38008392 TURNAROUND TIME: STND/BUT ASAP PWS #: 2646395
<b>PROJECT NAME:</b> 2025 Annual		<b>PROJECT #:</b> 107	<b>NUMBER OF CONTAINERS</b>	
<b>SAMPLE NUMBER</b> 107-21338	<b>DATE &amp; TIME OF SAMPLE COLLECTION</b> 1/14/25 0723	<b>SAMPLE DESCRIPTION AND PRODUCTION CODE</b> Spring Finished Product	ANALYSIS REQUIRED	
<b>LAB, PLEASE INDICATE DATE AND TIME BOTTLES OPENED (SAMPLE DATE &amp; TIME)</b>		Produced From: Spring 1 Size: 1.5 liter If multiple shipments indicate shipment 4 of 4	50-BAT1-FP, Plus PFAS (537.1)*	
<b>SAMPLER'S SIGNATURE:</b> 		PLEASE PRINT BELOW: Monica DeBrotte	COMPLIANCE CRITERIA: REPORT TO PA DEP	
<b>RELINQUISHED BY</b> 	<b>DATE/TIME</b> 1/14/25 0723	<b>ACCEPTED BY</b> 	<b>DATE/TIME</b> 1/17/25 1006	<b>NOTES TO LABORATORY</b> (631A) 2.4+0.3=2.7 NO ICE EEWAR *PLEASE PUT PFAS ON A SEPARATE REPORT UPS 1Z80FV91812 13028439



**Eurofins Eaton Analytical Pomona**  
 941 Corporate Center Drive  
 Pomona, CA 91768-2642  
 Phone: 626-386-1100

**Chain of Custody Record**



Environment Testing

<b>Client Information (Sub Contract Lab)</b>		Sampler	Lab P#	Carrier Tracking No(s)		COC No.																			
Arada, Rachelle		N/A	N/A	N/A		380-184289.1																			
Phone		E-Mail:		State of Origin:		Page																			
N/A		Rachelle.Arada@et.eurofins.com		Pennsylvania		Page 1 of 1																			
Company		Accreditations Required (See note)		Job #		Preservation Codes:																			
TestAmerica Laboratories, Inc.		N/A		N/A		380-131110-1																			
Address		Due Date Requested:		<b>Analysis Requested</b>																					
13715 Rider Trail North,		2/12/2025																							
City:		TAT Requested (days):																							
Earth City		N/A																							
State, Zip:																									
MO, 63045				Total Number of Containers																					
Phone:		PO #:		Other:																					
314-298-8566(Tel) 314-298-8757(Fax)		N/A		N/A																					
Email:		WO #:																							
N/A		N/A																							
Project Name:		Project #:																							
107-21338		38008392																							
Site:		SSOW#:																							
N/A		N/A																							
<b>Sample Identification - Client ID (Lab ID)</b>		<b>Sample Date</b>		<b>Sample Time</b>		<b>Sample Type (C=Comp, G=Grab)</b>		<b>Matrix (Water, Soil, Overstall, etc.)</b>		<b>Preservation Code:</b>		<b>Field Filtered Sample (Yes or No)</b>		<b>Perform MS/MSD (Yes or No)</b>		<b>Evaporation Standard Target List</b>		<b>903.0/PreSep, 7 903.0 Radium 226 7day IG</b>		<b>904.0/PreSep, 0 904.0 Radium 228</b>		<b>Ra226_228GFPC_P</b>		<b>Special Instructions/Note:</b>	
107-21338 Spring Finished Product (380-131110-1)		1/14/25		07:23 Eastern		G		Bottled Water														1 SDWA			
107-21338 Spring Finished Product (380-131110-1)		1/20/25		17:29 Pacific		G		Bottled Water														1 SDWA			
<p>Note: Since laboratory accreditations are subject to change, Eurofins Eaton Analytical, LLC places the ownership of method, analyze &amp; accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/matrix being analyzed, the samples must be shipped back to the Eurofins Eaton Analytical, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Eaton Analytical, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody atesting to Eurofins Eaton Analytical, LLC.</p>																									
<b>Possible Hazard Identification</b>																									
Unconfirmed																									
Deliverable Requested: I, II, III, IV, Other (specify) _____ Primary Deliverable Rank: 1																									
Empty Kit Relinquished by: _____ Date: _____ Method of Shipment: _____																									
Relinquished by: <i>Culler</i> Date/Time: <i>1-21-25 7:40</i> Company: _____																									
Relinquished by: _____ Date/Time: _____ Company: _____																									
Relinquished by: _____ Date/Time: _____ Company: _____																									
Custody Seals Intact: _____ Custody Seal No.: _____ Cooler Temperature(s) °C and Other Remarks: _____																									

