

CLIENT INFORMATION

Client: *****
Requested On: Mar 27, 2023
Phone: *****
Email: *****

hello@gosimplelab.com

Oak Ridge
Scarboro, South Carolina

TESTING PERFORMED

Testing Requested: Tritium Water Test
Matrix: Drinking Water
Testing / Report ID: X6LKUK

SAMPLE INFORMATION

Collection Date: Apr 30, 2023
Collected By: *****
Received Date: May 4, 2023
Reported On: May 23, 2023
Sample Location: Glass bottle
Sample Address: *****

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

| ANALYTE | UNIT | RESULT | MDL | METHOD | EVALUATION |
|---------|-------|--------------|-----|-----------|------------|
| Tritium | pCi/L | NOT DETECTED | 544 | EPA 906.0 | |

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.