

## CLIENT INFORMATION

Client: \*\*\*\*\*  
 Requested On: Sep 24, 2025  
 Phone: \*\*\*\*\*  
 Email: \*\*\*\*\*

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:  
[support@mytapscore.com](mailto:support@mytapscore.com)  
 Do not contact facility technicians directly.

## TESTING PERFORMED

Testing Requested: PFAS Water Test  
 Matrix: Drinking Water  
 Testing / Report ID: 5437QE  
 Testing Facility: Pace Analytical  
 Facility Location: 2231 W. Altorfer Dr.  
 Peoria, Illinois 61615

## SAMPLE INFORMATION

Collection Date: Sep 29, 2025  
 Collected By: \*\*\*\*\*  
 Received Date: Sep 30, 2025  
 Reported On: Oct 3, 2025  
 Sample Location: Source Tank  
 Sample Address: \*\*\*\*\*

## TESTING NOTES FROM TAP SCORE

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact [support@mytapscore.com](mailto:support@mytapscore.com)

## TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EPA REG
N-ethyl perfluorooctanesulfonamidoacetic acid	µg/L	< 0.0022	0.0006	0.0022	EPA 537.1	
N-methyl perfluorooctanesulfonamidoacetic acid	µg/L	< 0.0022	0.0004	0.0022	EPA 537.1	
Perfluorobutanesulfonic acid	µg/L	< 0.0022	0.0005	0.0022	EPA 537.1	
Perfluorodecanoic acid	µg/L	< 0.0022	0.0004	0.0022	EPA 537.1	
Perfluorododecanoic acid	µg/L	< 0.0022	0.0005	0.0022	EPA 537.1	
Perfluoroheptanoic acid	µg/L	< 0.0022	0.0004	0.0022	EPA 537.1	
Perfluorohexanesulfonic acid	µg/L	< 0.0022	0.0004	0.0022	EPA 537.1	< MCL (0.01)
Perfluorohexanoic acid	µg/L	< 0.0022	0.0004	0.0022	EPA 537.1	
Perfluorononanoic acid	µg/L	< 0.0022	0.0006	0.0022	EPA 537.1	< MCL (0.01)
Perfluorooctanesulfonic acid	µg/L	< 0.0022	0.0004	0.0022	EPA 537.1	< MCL (0.004)
Perfluorooctanoic acid	µg/L	< 0.0022	0.0005	0.0022	EPA 537.1	< MCL (0.004)
Perfluorotetradecanoic acid	µg/L	< 0.0022	0.0008	0.0022	EPA 537.1	
Perfluorotridecanoic acid	µg/L	< 0.0022	0.0006	0.0022	EPA 537.1	
Perfluoroundecanoic acid	µg/L	< 0.0022	0.0004	0.0022	EPA 537.1	

### How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

*MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.*

### **How To Read Your SimpleLab PDF Report**

*Your results are being evaluated with the Health Guidance Level.*

*This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.*

*MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team are configured to measure.*



## **Did you know?**

This Tap Score report is easier to understand when viewed online. Access in-depth information about every detection, including health risks and treatment solutions.

[gosimplelab.com/signin](https://gosimplelab.com/signin)