

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

CLIENT INFORMATION

Client: *****
Requested On: Nov 26, 2025
Phone: *****
Email: *****

Questions? For fastest assistance:
hello@gosimplelab.com
Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: Microplastics Water Test
Matrix: Drinking Water
Testing / Report ID: NJBMTU
Testing Facility: EMSL Analytical Inc
Facility Location: 200 Route 130 North
Cinnaminson, New Jersey 08077

SAMPLE INFORMATION

Collection Date: Dec 3, 2025
Collected By: *****
Received Date: Dec 5, 2025
Reported On: Dec 22, 2025
Sample Location: office
Sample Address: *****

TESTING NOTES FROM SIMPLELAB

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD
Microplastics (1000-5000 um)	Count/mL	NOT DETECTED	0.0014	0.0014	Microplastics - Fluorescence Microscopy (FLM)
Microplastics (100-500 um)	Count/mL	NOT DETECTED	0.0014	0.0014	Microplastics - Fluorescence Microscopy (FLM)
Microplastics (10-50 um)	Count/mL	NOT DETECTED	0.0014	0.0014	Microplastics - Fluorescence Microscopy (FLM)
Microplastics (<10 um)	P/A	NOT DETECTED			Microplastics - Fluorescence Microscopy (FLM)
Microplastics (500-1000 um)	Count/mL	NOT DETECTED	0.0014	0.0014	Microplastics - Fluorescence Microscopy (FLM)
Microplastics (50-100 um)	Count/mL	NOT DETECTED	0.0014	0.0014	Microplastics - Fluorescence Microscopy (FLM)

How To Read Your SimpleLab PDF Report

MDL: The Method Detection Limit is the lowest concentration which the analysis team and instrumentation is configured to measure.

RL: The Method Reporting Limit is the lowest level at which the laboratory can confidently and accurately quantify the concentration.