



789 N. Dixboro Rd. Ann Arbor, MI 48105, USA
1-800.NSF.MARK | +1-734.769.8010 | www.nsf.org

TEST REPORT

Send To: 16080

Mr. Mike Biddle
(Ozarka) Eureka Water Company
729 S.W. 3rd Street
Oklahoma City, OK 73109

Facility: 16080

(Ozarka) Eureka Water Company
729 S.W. 3rd Street
Oklahoma City OK 73109
United States

Result	PASS	Final Report Date	21-MAR-2025
Customer Name	(Ozarka) Eureka Water Company		
Tested To	USFDA CFR Title 21 Part 165.110		
Description	Drinking Water		
Test Type	Annual Collection		
Job Number	A-00503471		
Project Number	W0942958		
Project Manager	Luba Razhavsky		

Thank you for having your product tested by NSF.

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

Report Authorization

Nancy Cole - Director, Analysis Laboratories

Date

21-MAR-2025



General Information

Standard: USFDA CFR Title 21 Part 165.110

Collected by: Marya Strelkova

Lot Number: BEST BY: 2/13/27

Product Description: Drinking Water

Sample Id: S-0002194308

Description: Drinking Water | BEST BY: 2/13/27

Sampled Date: 02/24/2025

Received Date: 02/20/2025

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Physical Quality					
Alkalinity as CaCO ₃	5	28		mg CaCO ₃ /L	
Color	5	ND	15	Color Unit	Pass
Color Type		Apparent			
Specific Conductance	10	150		umhos/cm	
Temperature	0	22		degrees C	
Corrosivity		-1.02			
Hardness, Total	2	37		mg CaCO ₃ /L	
Solids Total Dissolved	5	85	500	mg/L	Pass
Turbidity	0.1	ND	5	NTU	Pass
pH	0.01	7.66			
Temperature	0	23		deg. C	
Odor, Threshold	1	1	3	TON	Pass
Temperature	0	60		deg_C	
Bicarbonate	5	27.52		mg CaCO ₃ /L	
Microbiological Quality					
Coliform in Water/100 mL		Absent			Pass
E. Coli in Water/100 mL		Absent			Pass
Disinfection Residuals/Disinfection By-Products					
Bromate	5	6	10	ug/L	Pass
Monochloramine	0.05	ND		mg/L	
Dichloramine	0.05	ND		mg/L	
Nitrogen trichloride	0.05	ND		mg/L	
Chloramine, Total	0.05	ND	4	mg/L	Pass
Chlorite	10	ND	1000	ug/L	Pass
Chlorine Dioxide	0.1	ND	0.8	mg/L	Pass
Monochloroacetic Acid	2	ND		ug/L	
Monobromoacetic Acid	1	ND		ug/L	
Dichloroacetic Acid	1	ND		ug/L	
Bromochloroacetic Acid	1	ND		ug/L	
Trichloroacetic Acid	1	ND		ug/L	
Dibromoacetic Acid	1	ND		ug/L	
Total Haloacetic Acid	1	ND	60	ug/L	Pass
Chlorine, Total Residual	0.05	ND	4	mg/L	Pass
Radiologicals					
Uranium	0.001	ND	0.03	mg/L	Pass
P1 Gross Alpha	3	ND	15	pCi/L	Pass
P1 Gross Beta	4	ND	50	pCi/L	Pass
Alpha Uncertainty +/-	0	1		pCi/L	
Beta Uncertainty +/-	0	1		pCi/L	
Inorganic Chemicals					



Sample Id: S-0002194308

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Inorganic Chemicals					
Aluminum	0.01	ND	0.2	mg/L	Pass
Antimony	0.0005	ND	0.006	mg/L	Pass
Arsenic	0.001	ND	0.01	mg/L	Pass
Barium	0.001	ND	2	mg/L	Pass
Beryllium	0.0002	ND	0.004	mg/L	Pass
Bromide	10	ND		ug/L	
Cadmium	0.0002	ND	0.005	mg/L	Pass
Calcium	0.02	14		mg/L	
Chloride	2	30	250	mg/L	Pass
Chromium (includes Hexavalent Chromium)	0.001	ND	0.1	mg/L	Pass
Copper	0.001	ND	1	mg/L	Pass
Cyanide, Total	0.005	ND	0.2	mg/L	Pass
Fluoride	0.1	ND		mg/L	
Iron	0.02	ND	0.3	mg/L	Pass
Lead	0.0005	ND	0.005	mg/L	Pass
Magnesium	0.02	0.62		mg/L	
Manganese	0.001	ND	0.05	mg/L	Pass
Mercury	0.0002	ND	0.002	mg/L	Pass
Nickel	0.0005	ND	0.1	mg/L	Pass
Nitrogen, Nitrate	0.01	ND	10	mg/L N	Pass
Nitrogen, Nitrite	0.004	ND	1	mg/L N	Pass
Total Nitrate + Nitrite-Nitrogen	0.01	ND	10	mg/L	Pass
Potassium	0.5	ND		mg/L	
Selenium	0.001	ND	0.05	mg/L	Pass
Silver	0.001	ND	0.1	mg/L	Pass
Sodium	0.2	13		mg/L	
Sulfate as SO4	0.5	ND	250	mg/L	Pass
MBAS, calc. as LAS Mol.Wt. 320	0.2	ND		mg/L	
Thallium	0.0002	ND	0.002	mg/L	Pass
Zinc	0.01	ND	5	mg/L	Pass
Chrysotile Fibers	0.2	ND		MFL	
Amphibole Fibers	0.2	ND		MFL	
Single Fiber Detection Limit	0.2	ND		MFL	
Organic Chemicals					
Diquat (Ref: EPA 549.2)					
Diquat	0.4	ND	20	ug/L	Pass
Endothall (Ref: EPA 548.1) - (ug/L)					
Endothall	2	ND	100	ug/L	Pass
Glyphosate (Ref: EPA 547)					
Glyphosate	6	ND	700	ug/L	Pass
Perchlorate (Ref: EPA 314.0)					
Perchlorate	1	ND		ug/L	
2,3,7,8-TCDD (Ref: EPA 1613B)					
2,3,7,8-Tetrachlorodibenzo-p-dioxin	5	ND	30	pg/L	Pass
Semivolatile Organic Compounds (Ref: EPA 525.2)					
Hexachlorocyclopentadiene	0.1	ND	50	ug/L	Pass
EPTC	0.5	ND		ug/L	
Dimethylphthalate	2	ND		ug/L	
2,6-Dinitrotoluene	0.5	ND		ug/L	



Sample Id: S-0002194308

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
2,4 Dinitrotoluene	0.5	ND		ug/L	
Molinate	0.1	ND		ug/L	
Diethylphthalate	2	ND		ug/L	
Propachlor	0.1	ND		ug/L	
Hexachlorobenzene	0.1	ND	1	ug/L	Pass
Simazine	0.07	ND	4	ug/L	Pass
Atrazine	0.1	ND	3	ug/L	Pass
Lindane	0.02	ND	0.2	ug/L	Pass
Terbacil	0.5	ND		ug/L	
Metribuzin	0.1	ND		ug/L	
Alachlor	0.1	ND	2	ug/L	Pass
Heptachlor	0.04	ND	0.4	ug/L	Pass
Di-n-butylphthalate	2	ND		ug/L	
Metolachlor	0.1	ND		ug/L	
Aldrin	0.08	ND		ug/L	
Heptachlor Epoxide	0.02	ND	0.2	ug/L	Pass
Butachlor	0.2	ND		ug/L	
p,p'-DDE (4,4'-DDE)	0.5	ND		ug/L	
Dieldrin	0.5	ND		ug/L	
Endrin	0.1	ND	2	ug/L	Pass
Butylbenzylphthalate	2	ND		ug/L	
bis(2-Ethylhexyl)adipate	0.6	ND	400	ug/L	Pass
Methoxychlor	0.1	ND	40	ug/L	Pass
bis(2-Ethylhexyl)phthalate (DEHP)	0.6	ND	6	ug/L	Pass
Benzo(a)Pyrene	0.02	ND	0.2	ug/L	Pass
Volatiles: EDB and DBCP (Ref: EPA 504.1)					
Ethylene Dibromide (EDB)	0.01	ND	0.05	ug/L	Pass
1,2-Dibromo-3-Chloropropane (DBCP)	0.01	ND	0.2	ug/L	Pass
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)					
Dichlorodifluoromethane	0.5	ND		ug/L	
Chloromethane	0.5	ND		ug/L	
Vinyl Chloride	0.5	ND	2	ug/L	Pass
Bromomethane	0.5	ND		ug/L	
Chloroethane	0.5	ND		ug/L	
Trichlorofluoromethane	0.5	ND		ug/L	
Trichlorotrifluoroethane	0.5	ND		ug/L	
Methylene Chloride	0.5	ND	5	ug/L	Pass
1,1-Dichloroethylene	0.5	ND	7	ug/L	Pass
trans-1,2-Dichloroethylene	0.5	ND	100	ug/L	Pass
1,1-Dichloroethane	0.5	ND		ug/L	
2,2-Dichloropropane	0.5	ND		ug/L	
cis-1,2-Dichloroethylene	0.5	ND	70	ug/L	Pass
Chloroform	0.5	ND		ug/L	
Bromochloromethane	0.5	ND		ug/L	
1,1,1-Trichloroethane	0.5	ND	200	ug/L	Pass
1,1-Dichloropropene	0.5	ND		ug/L	
Carbon Tetrachloride	0.5	ND	5	ug/L	Pass
1,2-Dichloroethane	0.5	ND	5	ug/L	Pass
Trichloroethylene	0.5	ND	5	ug/L	Pass



Sample Id: S-0002194308

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
1,2-Dichloropropane	0.5	ND	5	ug/L	Pass
Bromodichloromethane	0.5	ND		ug/L	
Dibromomethane	0.5	ND		ug/L	
cis-1,3-Dichloropropene	0.5	ND		ug/L	
trans-1,3-Dichloropropene	0.5	ND		ug/L	
1,1,2-Trichloroethane	0.5	ND	5	ug/L	Pass
1,3-Dichloropropane	0.5	ND		ug/L	
Tetrachloroethylene	0.5	ND	5	ug/L	Pass
Chlorodibromomethane	0.5	ND		ug/L	
Chlorobenzene	0.5	ND	100	ug/L	Pass
1,1,1,2-Tetrachloroethane	0.5	ND		ug/L	
Bromoform	0.5	ND		ug/L	
1,1,2,2-Tetrachloroethane	0.5	ND		ug/L	
1,2,3-Trichloropropane	0.5	ND		ug/L	
1,3-Dichlorobenzene	0.5	ND		ug/L	
1,4-Dichlorobenzene	0.5	ND	75	ug/L	Pass
1,2-Dichlorobenzene	0.5	ND	600	ug/L	Pass
Methyl-tert-Butyl Ether (MTBE)	0.5	ND		ug/L	
Toluene	0.5	ND	1000	ug/L	Pass
Ethyl Benzene	0.5	ND	700	ug/L	Pass
m+p-Xylenes	1	ND		ug/L	
o-Xylene	0.5	ND		ug/L	
Styrene	0.5	ND	100	ug/L	Pass
Isopropylbenzene (Cumene)	0.5	ND		ug/L	
n-Propylbenzene	0.5	ND		ug/L	
Bromobenzene	0.5	ND		ug/L	
2-Chlorotoluene	0.5	ND		ug/L	
4-Chlorotoluene	0.5	ND		ug/L	
1,3,5-Trimethylbenzene	0.5	ND		ug/L	
tert-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trimethylbenzene	0.5	ND		ug/L	
sec-Butylbenzene	0.5	ND		ug/L	
p-Isopropyltoluene (Cymene)	0.5	ND		ug/L	
1,2,3-Trimethylbenzene	0.5	ND		ug/L	
n-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trichlorobenzene	0.5	ND	70	ug/L	Pass
Hexachlorobutadiene	0.5	ND		ug/L	
1,2,3-Trichlorobenzene	0.5	ND		ug/L	
Naphthalene	0.5	ND		ug/L	
Benzene	0.5	ND	5	ug/L	Pass
Total Trihalomethanes	0.5	ND	80	ug/L	Pass
Total Xylenes	0.5	ND	10000	ug/L	Pass
Chlorinated Pesticides and Organohalides by EPA 508.1					
Toxaphene	0.1	ND	3	ug/L	Pass
Chlordane	0.1	ND	2	ug/L	Pass
PCB 1016	0.08	ND	0.5	ug/L	Pass
PCB 1221	0.1	ND	0.5	ug/L	Pass
PCB 1232	0.1	ND	0.5	ug/L	Pass
PCB 1242	0.1	ND	0.5	ug/L	Pass



Sample Id: S-0002194308

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
PCB 1248	0.1	ND	0.5	ug/L	Pass
PCB 1254	0.1	ND	0.5	ug/L	Pass
PCB 1260	0.1	ND	0.5	ug/L	Pass
Endrin	0.01	ND	2	ug/L	Pass
Total PCBs	0.1	ND	0.5	ug/L	Pass
* Herbicides (Ref: EPA 515.4)					
Dalapon	1	ND	200	ug/L	Pass
Dicamba	0.1	ND		ug/L	
2,4-D	0.1	ND	70	ug/L	Pass
Pentachlorophenol	0.04	ND	1	ug/L	Pass
2,4,5-TP	0.2	ND	50	ug/L	Pass
Dinoseb	0.2	ND	7	ug/L	Pass
Picloram	0.1	ND	500	ug/L	Pass
Bentazon	0.2	ND		ug/L	
DCPA Acid Metabolites	0.2	ND		ug/L	
Miscellaneous					
Radium-226	5	ND		pCi/L	
Radium-228	5	ND		pCi/L	
Radium-226, Radium-228 Combined	5	ND	5	pCi/L	Pass
Radium 226 Uncertainty +/-	0	0.1		pCi/L	
Radium 228 Uncertainty +/-	0	0.4		pCi/L	
Phenolics	0.001	ND	0.001	mg/L	Pass
3-Hydroxycarbofuran	0.5	ND		ug/L	
Aldicarb	0.5	ND		ug/L	
Aldicarb sulfone	0.7	ND		ug/L	
Aldicarb sulfoxide	0.5	ND		ug/L	
Carbaryl	0.5	ND		ug/L	
Carbofuran	0.9	ND	40	ug/L	Pass
Methomyl	0.5	ND		ug/L	
Oxamyl	1	ND	200	ug/L	Pass



<<Additional Information>>

Sample Id: S-0002194308

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Physical Quality			
Alkalinity (Ref: SM 2320-B)	26-FEB-2025		
Test Notes For alkalinity greater than or equal to 20mg CaCO ₃ /L, the pH endpoint is 4.5.			
Color (Ref: SM 2120-B)	24-FEB-2025	11:37	
Specific Conductance at 25°C (Ref: EPA 120.1)	24-FEB-2025		
Corrosivity (Ref: SM 2330-B)			
Test Notes The corrosivity calculation uses half of the reporting limit for any calcium and/or bicarbonate/alkalinity value that has a result of less than the reporting limit.			
Hardness, Total (Ref: EPA 200.7)			
Solids, Total Dissolved (Ref: SM 2540-C)	26-FEB-2025		
Turbidity (Ref: EPA 180.1)	24-FEB-2025	12:21	
pH (Ref: SM4500-HB)	24-FEB-2025	10:57	
Odor, Threshold Number (Ref. Standard Methods 2150 B)	24-FEB-2025	14:56	
Bicarbonate (Ref: SM 2320-B)			
Microbiological Quality			
#4 Coliforms and E. coli (Ref: SM 9223)- Performed at NSF Approved Subcontract Laboratory			25-FEB-2025 12:57
Disinfection Residuals/Disinfection By-Products			
Bromate (Ref: EPA 300.1)	28-FEB-2025		
Chloramines (Ref: SM 4500-Cl-G)	24-FEB-2025	10:56	
Chlorite (Ref: EPA 300.1)	25-FEB-2025		
Chlorine Dioxide (Ref: SM 4500-ClO ₂ -D)	24-FEB-2025	10:56	
Haloacetic Acids (Ref: EPA 552.2)	3-MAR-2025		1-MAR-2025
Chlorine, Total Residual (ref. SM 4500CL-G)	24-FEB-2025	10:56	
Radiologicals			
Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Gross Alpha and Beta Radioactivity in Drinking Water (Ref: EPA 900.0)	28-FEB-2025		
Inorganic Chemicals			
Aluminum (Ref: EPA 200.8)	27-FEB-2025		
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Bromide (Ref: EPA 300.1)	25-FEB-2025		
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)	27-FEB-2025		



<<Additional Information>>

Sample Id: S-0002194308

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Inorganic Chemicals			
Chloride (Ref: EPA 300.0)	24-FEB-2025		
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Cyanide, Total (Ref: EPA 335.4)	26-FEB-2025		
Fluoride (Ref: SM 4500-F-C)	25-FEB-2025		
Iron in Drinking Water by ICPAES (Ref: EPA 200.7)	27-FEB-2025		
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)	27-FEB-2025		
Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Nitrogen, Nitrate (Ref: EPA 300.0)	24-FEB-2025	14:08	
Nitrogen, Nitrite (Ref: EPA 300.0)	24-FEB-2025	14:08	
Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)			
Potassium by ICPAES (Ref: EPA 200.7)	27-FEB-2025		
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Silver in Drinking Water by ICPMS (Ref: EPA 200.8) for BQ	7-MAR-2025		6-MAR-2025
Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)	27-FEB-2025		
Sulfate as SO4 (Ref: EPA 300.0)	24-FEB-2025		
Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)	24-FEB-2025	11:55	
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)	27-FEB-2025		
#2 * Asbestos in Water (Ref: EPA 100.2)- EMSL	10-MAR-2025	00:00	25-FEB-2025 13:26
Organic Chemicals			
Diquat (Ref: EPA 549.2)	28-FEB-2025		27-FEB-2025
Endothall (Ref: EPA 548.1) - (ug/L)	3-MAR-2025		28-FEB-2025
Glyphosate (Ref: EPA 547)	27-FEB-2025		
Perchlorate (Ref: EPA 314.0)	4-MAR-2025		
2,3,7,8-TCDD (Ref: EPA 1613B)	18-MAR-2025		12-MAR-2025
Semivolatile Organic Compounds (Ref: EPA 525.2)	26-MAR-2025		25-MAR-2025
Volatiles: EDB and DBCP (Ref: EPA 504.1)	25-FEB-2025		
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)	24-FEB-2025		
Chlorinated Pesticides and Organohalides by EPA 508.1	27-FEB-2025		
* Herbicides (Ref: EPA 515.4)	27-FEB-2025		



<<Additional Information>>

Sample Id: S-0002194308

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Organic Chemicals			27-FEB-2025
Miscellaneous			
#1 * Carbamate Pesticides (Ref. EPA 531.2) by NSF Approved Subcontract Laboratory	26-FEB-2025		
#3 * Radium-226, Radium-228 Combined Activity - General Engineering	5-MAR-2025		
#3 * Radium-226, Radium-228 Combined Activity - General Engineering	7-MAR-2025		
#4 *Phenolics,Total Recoverable (EPA 420.4) National Testing Laboratories, Ltd.	25-FEB-2025	00:00	



Job Notes:

The NSF Ann Arbor Laboratory is currently in applied status for certification for the state of California (#03214 CA). The applied status is based on a recent change in the CA reciprocity certification requirements and is not reflective of any change in quality for the NSF Ann Arbor Laboratory.



Testing Laboratories:

Flag	Id	Address
All work performed at: (Unless otherwise specified) → NSF_AA		
#4	EEA	NSF 789 N. Dixboro Road Ann Arbor MI 48105
#1	EMSL	Eurofins Eaton Analytical, Inc. 750 Royal Oaks Dr, Suite 100 Monrovia, CA 91016 NY Lic. # 11320 MI Lic. # 9906
#3	GENENG	EMSL Analytical Inc. 200 Route 130 North Cinnaminson, NJ 08077 USA NY Lic. # 10872
#2	NTL	GEL Laboratories LLC 2040 Savage Road Charleston, SC 29407 NELAP PA certificate number 68-000485 Arizona License #AZ0668 NY Lic. # 11501 MI Lic. # 9976
		National Testing Laboratories, LTD. 556 S. Mansfield Ypsilanti, MI 48197 USA NY Lic. # 11467

References to Testing Procedures:

NSF Reference	Parameter / Test Description
C0104	* Radium-226, Radium-228 Combined Activity - General Engineering
C0842	Gross Alpha and Beta Radioactivity in Drinking Water (Ref: EPA 900.0)
C1188	Odor, Threshold Number (Ref. Standard Methods 2150 B)
C1295	Silver in Drinking Water by ICPMS (Ref: EPA 200.8) for BQ
C1302	* Herbicides (Ref: EPA 515.4)
C1361	Bicarbonate (Ref: SM 2320-B)
C1536	* Asbestos in Water (Ref: EPA 100.2)- EMSL
C1565	*Phenolics, Total Recoverable (EPA 420.4) National Testing Laboratories, Ltd.
C1933	* Carbamate Pesticides (Ref. EPA 531.2) by NSF Approved Subcontract Laboratory
C2015	2,3,7,8-TCDD (Ref: EPA 1613B)
C3013	Chloride (Ref: EPA 300.0)
C3014	Bromide (Ref: EPA 300.1)
C3015	Bromate (Ref: EPA 300.1)
C3016	Nitrogen, Nitrate (Ref: EPA 300.0)
C3017	Nitrogen, Nitrite (Ref: EPA 300.0)
C3018	Sulfate as SO4 (Ref: EPA 300.0)
C3019	Cyanide, Total (Ref: EPA 335.4)
C3025	Chlorite (Ref: EPA 300.1)
C3033	Aluminum (Ref: EPA 200.8)
C3036	Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3039	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3042	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3044	Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3047	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3053	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3059	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)



References to Testing Procedures: (Cont'd)

NSF Reference	Parameter / Test Description
C3064	Iron in Drinking Water by ICPAES (Ref: EPA 200.7)
C3072	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3079	Potassium by ICPAES (Ref: EPA 200.7)
C3085	Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3086	Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)
C3091	Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3094	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3101	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)
C3114	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3116	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3128	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3136	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C3144	Solids, Total Dissolved (Ref: SM 2540-C)
C3145	Turbidity (Ref: EPA 180.1)
C3155	Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)
C3157	Color (Ref: SM 2120-B)
C3158	Specific Conductance at 25°C (Ref: EPA 120.1)
C3159	pH (Ref: SM4500-HB)
C3161	Hardness, Total (Ref: EPA 200.7)
C3168	Chlorine Dioxide (Ref: SM 4500-ClO ₂ -D)
C3169	Chloramines (Ref: SM 4500-Cl-G)
C3170	Fluoride (Ref: SM 4500-F-C)
C3174	Alkalinity (Ref: SM 2320-B)
C3210	Corrosivity (Ref: SM 2330-B)
C3342	Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)
C3393	Chlorine, Total Residual (ref. SM 4500CL-G)
C4145	Diquat (Ref: EPA 549.2)
C4154	Endothall (Ref. EPA 548.1) - (ug/L)
C4193	Glyphosate (Ref: EPA 547)
C4198	Haloacetic Acids (Ref: EPA 552.2)
C4343	Semivolatile Organic Compounds (Ref: EPA 525.2)
C4411	Volatiles: EDB and DBCP (Ref: EPA 504.1)
C4496	Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)
C4497	Perchlorate (Ref: EPA 314.0)
C4661	Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)
C4669	Chlorinated Pesticides and Organohalides by EPA 508.1
M1115	Coliforms and E. coli (Ref: SM 9223)- Performed at NSF Approved Subcontract Laboratory

Laboratory Certifications:

Arizona (# AZ0655)	Connecticut (# PH-0625)	Florida (# E-87752 FL)
Hawaii	Indiana	Maryland (# 201)
Michigan (# 0048)	North Carolina (# 26701)	New Jersey (# MI770)
Nevada (# MI000302010A)	New York (# 11206)	Pennsylvania (# 68-00312)
South Carolina (# 81005)	Virginia (# 00045)	Vermont (# VT 11206)



Test descriptions preceded by an asterisk "*" indicate that testing has been performed per NSF requirements but is not within its 17025 scope of accreditation.

Unless otherwise indicated, method uncertainties are not applied in any determinations of conformity. Testing utilizes the requested sections of any referenced standards, which may not be the entire standard.

Dates of Laboratory Activity: 24-FEB-2025 to 21-MAR-2025

The reported result for Total Recoverable Phenolics, Potassium, Molybdenum, Silica, Total Phosphorus, Radon, Sr-89/90, Bicarbonate, Bromochloroacetic Acid, Total Haloacetic acid, Bentazon, DCPA Acid Metabolites, EPTC, Dimethylphthalate, 2,6-Dinitrotoluene, 2,4-Dinitrotoluene, Molinate, Diethylphthalate, Terbacil, Di-n-butylphthalate, p,p'-DDE (4,4'-DDE), Butylbenzylphthalate, Trichlorotrifluoroethane, Methyl Ethyl Ketone, 1,2,3-Trimethylbenzene, Epichlorohydrin, or 1,4-Dioxane if performed, cannot be used for compliance purposes within the State of Arizona. Certifications are not offered for these compounds in a drinking water matrix.

The reported results for Total Recoverable Phenolics, pH, Bicarbonate and Temperature, if performed, are not covered by New York State drinking water certifications. NSF is not certified for Carbamate Pesticides, Total Radium-226, Radium-228 Combined Activity, Chlorine Dioxide, Chloramines, Total Residual Chlorine, Total Haloacetic acid, Bentazon, DCPA Acid Metabolites, EPTC, Dimethylphthalate, 2,6-Dinitrotoluene, 2,4-Dinitrotoluene, Molinate, Diethylphthalate, Terbacil, Di-n-butylphthalate, p,p'-DDE (4,4'-DDE), Butylbenzylphthalate, Trichlorotrifluoroethane, Methyl Ethyl Ketone, 1,2,3-Trimethylbenzene, Epichlorohydrin, or 1,4-Dioxane in the State of New York.

Notes:

- 1) Bottled water sold in the United States shall not contain Fluoride in excess of the levels published by the USFDA in 21 CFR Part 165.110. These levels are based on the annual average of maximum daily air temperatures at the location where the bottled water is sold at retail. Please refer to the most current edition of the regulation to determine the Fluoride maximum level that pertains to your product.
- 2) A blank on the FDA SOQ column indicates that no maximum level has been established by the FDA for that contaminant.
- 3) An ND result means that the contaminant was not detected at or above the reporting limit.

For a list of NSF Method Detection Limits refer to

https://d2evkimvhatqav.cloudfront.net/documents/external/minimum_detection_level_spreadsheet.pdf