

2025 BOTTLED WATER QUALITY REPORT
ETERNAL SPRING WATER

Bottler's Name: Eternal Water
Address: 455 Great Smoky Mountains Rd.; Newport, TN 37821
Telephone Number: 800-489-1435
Source(s): Proffit Spring Source
Treatment process: Filtration, Ozonation

DEFINITIONS:

- **Statement of quality:** The quality standards of bottled water provide the maximum legal limits for a variety of substances that are allowed in bottled water, along with their monitoring requirements. The substances include microbiological contaminants, pesticides, inorganic contaminants, organic contaminants, radiological contaminants, and others. The standards have been established by the United States Food and Drug Administration (FDA), based on the public drinking water standards of the United States Environmental Protection Agency (USEPA). CDPH adopts the FDA regulations pertinent to the quality standards of bottled water.
- **Maximum contaminant level (MCL):** MCL is the maximum level of a contaminant allowed in public drinking water.
- **Primary drinking water standards (PDWS):** PDWS are set to provide the maximum feasible protection to public health. The goal of setting PDWS is to identify MCLs, along with their monitoring and reporting requirements, which prevent adverse health effects. PDWS are established as close to the public health goal (PHG) or the maximum contaminant level goal (MCLG) as is economically and technologically feasible.
- **Public health goal (PHG):** PHG is the level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

SOURCE WATER:

Eternal spring water is sourced only from natural springs. Other bottled water products may come from any of the sources listed below.

The sources of bottled water include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water naturally travels over the surface of the land or through the ground, it can pick up naturally occurring substances as well as substances that are present due to animal and human activity. Substances that may be present in the source water include any of the following:

- (1) Inorganic substances, including, but not limited to, salts and metals, that can be naturally occurring or result from farming, urban storm water runoff, industrial or domestic wastewater discharges, or oil and gas production.
- (2) Pesticides and herbicides that may come from a variety of sources, including, but not limited to, agriculture, urban storm water runoff, and residential uses.
- (3) Organic substances that are byproducts of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
- (4) Microbial organisms that may come from wildlife, agricultural livestock operations, sewage treatment plants, and septic systems.
- (5) Substances with radioactive properties that can be naturally occurring or be the result of oil and gas production and mining activities.”

CONTAMINANTS IN WATER:

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the United States Food and Drug Administration, Food and Cosmetic Hotline (1-888-723-3366). In order to ensure that bottled water is safe to drink, the United States Food and Drug Administration and the State Department of Public Health prescribe laws and regulations that limit the amount of certain contaminants in water provided by bottled water companies.

Some persons may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons, including, but not limited to, persons with cancer who are undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, some elderly persons, and infants can be particularly at risk from infections. These persons should seek advice about drinking water from their health care providers. The United States Environmental Protection Agency and the Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

INFORMATION on PRODUCT RECALLS:

If you would like to know whether a particular bottled water product has been recalled or is being recalled, please visit the FDA's website [**http://www.fda.gov/opacom/7alerts.html**](http://www.fda.gov/opacom/7alerts.html).

Compliance Designs

NOTE: “**” indicates that maximum levels have been exceeded, or in the case of pH, is either too high or too low
 “ND” indicates that none of this analyte has been detected at or above the specified detection level
 “MCL” indicates maximum contaminant level as established by US FDA for bottled water
 “RL” indicates laboratory reporting limit for method
 Units results are reported in mg/L unless otherwise noted

ANALYSIS PERFORMED	MCL ¹ (mg/L)	RL (mg/L)	ETERNAL SPRING WATER (Produced from Proffit Spring Source)
Primary Inorganics			
Antimony	0.006	0.001	ND
Arsenic	0.01	0.002	ND
Asbestos	7 MFL	0.177	ND
Barium	2	0.002	0.074
Beryllium	0.004	0.0003	ND
Cadmium	0.005	0.0005	ND
Chromium	0.1	0.0009	ND
Cyanide	0.2	0.025	ND
Fluoride	See endnote ²	0.05	0.051
Lead	0.005	0.0005	ND
Mercury	0.002	0.0002	ND
Nickel	0.1	0.001	ND
Nitrate – N	10	0.05	0.14
Nitrite – N	1.0	0.05	ND
Total Nitrate & Nitrite – N	10	0.05	0.14
Selenium	0.05	0.002	ND
Thallium	0.002	0.0003	ND
Secondary Inorganics			
Alkalinity	--	4	91
Aluminum	0.2	0.02	ND
Bicarbonate	--	4	91
Boron	--	0.05	ND
Bromide	--	0.005	ND
Calcium	--	0.10	20
Carbonate	--	4	ND
Chloride	250 ³	0.50	ND
Copper	1	0.001	ND
Corrosivity	--	-14	0.051
Foaming Agents	--	0.1	ND
Hardness, Calcium	--	2.5	49
Hardness, Total	--	2.9	96
Iron	0.3 ³	0.01	ND
Magnesium	--	0.1	11
Manganese	0.05 ³	0.002	ND
pH	See endnote ⁴	0.01	8.1
Phenol	0.001	0.001	ND
Potassium	--	0.10	1.4
Silver	0.1	0.0005	ND
Sodium	--	0.10	0.58
Specific Conductance	-- umho/cm	2.0	190
Sulfate	250	0.25	5.7
TDS	500 ^{3,5}	20	110
Zinc	5 ³	0.005	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	ETERNAL SPRING WATER (Produced from Proffit Spring Source)
Physical			
Color	15 ³ CU	2	2.0
Odor	3 ³ TON	1	ND
Turbidity	5 NTU	0.1	ND
Radiologicals			
Gross Alpha	15 pCi/L	3	ND
Gross Beta	50 pCi/L ⁵	4	ND
Radium 226/228	5 pCi/L	1 / 1	ND / ND
Uranium	0.030	0.001	ND
Volatile Organic Compounds EPA 524.2:			
Total Trihalomethanes	0.080	0.0005	ND
tert-Amyl Methyl Ether (TAME)	--	0.003	ND
tert-Butyl-Ethyl Ether (TBEE)	--	0.003	ND
Benzene	0.005	0.0005	ND
Bromobenzene	--	0.0005	ND
Bromochloromethane	--	0.0005	ND
Bromodichloromethane	--	0.0005	ND
Bromoform	--	0.0005	ND
Bromomethane	--	0.0005	ND
n-Butylbenzene	--	0.0005	ND
sec-Butylbenzene	--	0.0005	ND
tert-Butylbenzene	--	0.0005	ND
Carbon Disulfide	--	0.0005	ND
Carbon Tetrachloride	0.005	0.0005	ND
Chlorobenzene	0.1	0.0005	ND
Chloroethane	--	0.0005	ND
Chloroform	--	0.0005	ND
Chloromethane	--	0.0005	ND
2-Chlorotoluene	--	0.0005	ND
4-Chlorotoluene	--	0.0005	ND
Chlorodibromomethane	--	0.0005	ND
Dibromomethane	--	0.0005	ND
1,2-Dichlorobenzene	0.6	0.0005	ND
1,3-Dichlorobenzene	--	0.0005	ND
1,4-Dichlorobenzene	0.075	0.0005	ND
Dichlorodifluoromethane	--	0.0005	ND
1,1-Dichloroethane	--	0.0005	ND
1,2-Dichloroethane	0.005	0.0005	ND
1,1-Dichloroethylene	0.007	0.0005	ND
cis-1,2-Dichloroethylene	0.07	0.0005	ND
trans-1,2-Dichloroethylene	0.1	0.0005	ND
1,2-Dichloropropane	0.005	0.0005	ND
1,3-Dichloropropane	--	0.0005	ND
2,2-Dichloropropane	--	0.0005	ND
1,1-Dichloropropene	--	0.0005	ND
cis-1,3-Dichloropropene	--	0.0005	ND
trans-1,3-Dichloropropene	--	0.0005	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	ETERNAL SPRING WATER (Produced from Proffit Spring Source)
EPA 524.2 continued:			
Di-Isopropyl Ether	--	0.003	ND
Ethylbenzene	0.7	0.0005	ND
Hexachlorobutadiene	--	0.0005	ND
Isopropylbenzene	--	0.0005	ND
4-Isopropyltoluene	--	0.0005	ND
Methyl tert-Butyl Ether (MTBE)	--	0.0005	ND
Methyl Ethyl Ketone (MEK)	--	0.005	ND
Methylene Chloride	0.005	0.0005	ND
Naphthalene	--	0.0005	ND
n-Propylbenzene	--	0.0005	ND
Styrene	0.1	0.0005	ND
1,1,1,2-Tetrachloroethane	--	0.0005	ND
1,1,2,2-Tetrachloroethane	--	0.0005	ND
Tetrachloroethylene	0.005	0.0005	ND
Toluene	1	0.0005	ND
1,2,3-Trichlorobenzene	--	0.0005	ND
1,2,4-Trichlorobenzene	0.07	0.0005	ND
1,1,1-Trichloroethane	0.2	0.0005	ND
1,1,2-Trichloroethane	0.005	0.0005	ND
Trichloroethylene	0.005	0.0005	ND
Trichlorofluoromethane	--	0.0005	ND
Trichlorotrifluoroethane	--	0.0005	ND
1,2,3-Trichloropropane	--	0.0005	ND
1,2,4-Trimethylbenzene	--	0.0005	ND
1,3,5-Trimethylbenzene	--	0.0005	ND
Vinyl Chloride	0.002	0.0003	ND
m+p-Xylenes	--	0.0005	ND
ortho-Xylene	--	0.0005	ND
Total Xylene	10	0.0005	ND
Add'l Organics			
EPA 504.1:			
Ethylene Dibromide	0.00005	0.00001	ND
Dibromochloropropane	0.0002	0.00001	ND
1,2,3-Trichloropropane	--	0.00002	ND
EPA 505:			
Chlordane (alpha and gamma)	0.002	0.0001	ND
Total PCBs	0.0005	0.0001	ND
PCB 1016	--	0.00007	ND
PCB 1221	--	0.0001	ND
PCB 1232	--	0.0001	ND
PCB 1242	--	0.0001	ND
PCB 1248	--	0.0001	ND
PCB 1254	--	0.0001	ND
PCB 1260	--	0.00007	ND
Toxaphene	0.003	0.0005	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	ETERNAL SPRING WATER (Produced from Proffit Spring Source)
EPA 515.4:			
Acifluorfen	--	0.0002	ND
Bentazon	--	0.0005	ND
2,4-D	0.07	0.0001	ND
2,4-DB	--	0.002	ND
Dalapon	0.2	0.001	ND
Dicamba	--	0.0001	ND
3,5-Dichlorobenzoic Acid	--	0.0005	ND
Dichlorprop	--	0.0005	ND
Dinoseb	0.007	0.0002	ND
Pentachlorophenol	0.001	0.00004	ND
Picloram	0.5	0.0001	ND
2,4,5-T	--	0.0002	ND
2,4,5-TP (Silvex)	0.05	0.0001	ND
EPA 525.2:			
Acenaphthene	--	0.0001	ND
Acenaphthylene	--	0.0001	ND
Acetochlor	--	0.0001	ND
Alachlor	0.002	0.00005	ND
Aldrin	--	0.00001	ND
Alpha-BHC	--	0.0001	ND
Anthracene	--	0.00002	ND
Atrazine	0.003	0.00005	ND
Benz(a)Anthracene	--	0.00005	ND
Benzo(a)Pyrene	0.0002	0.00002	ND
Benzo(b)Fluoranthene	--	0.00002	ND
Benzo(g,h,i)Perylene	--	0.00005	ND
Benzo(k)Fluoranthene	--	0.00002	ND
Beta-BHC	--	0.0001	ND
Bromacil	--	0.0001	ND
Butylbenzylphthalate	--	0.0005	ND
Butachlor	--	0.00005	ND
Chlordane (alpha)	0.002	0.00005	ND
Chlordane (gamma)	0.002	0.00005	ND
Chlorobenzilate	--	0.0001	ND
Chloroneb	--	0.0001	ND
Chlorothalonil	--	0.0001	ND
Chlorpyrifos	--	0.00005	ND
Chrysene	--	0.00002	ND
Delta-BHC	--	0.0001	ND
4,4-DDD	--	0.0001	ND
4,4-DDE	--	0.0001	ND
4,4-DDT	--	0.0001	ND
Diazinon (Qualitative)	--	0.0001	ND
Dichlorvos (DDVP)	--	0.00005	ND
Di(2-ethylhexyl)Adipate	0.4	0.0006	ND
Dibenz(a,h)Anthracene	--	0.00005	ND
Di(2-ethylhexyl)Phthalate	0.006	0.0006	ND
Dieldrin	--	0.00001	ND
Diethylphthalate	--	0.0005	ND
Dimethylphthalate	--	0.0005	ND
Dimethoate	--	0.0001	ND
Di-n-Butylphthalate	--	0.001	ND
Di-n-Octylphthalate	--	0.0001	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	ETERNAL SPRING WATER (Produced from Proffit Spring Source)
EPA 525.2 continued:			
2,4-Dinitrotoluene	--	0.0001	ND
2,6-Dinitrotoluene	--	0.0001	ND
Endosulfan I (Alpha)	--	0.0001	ND
Endosulfan II (Beta)	--	0.0001	ND
Endosulfan Sulfate	--	0.0001	ND
Endrin	0.002	0.00001	ND
Endrin Aldehyde	--	0.0001	ND
EPTC	--	0.0001	ND
Fluoranthene	--	0.0001	ND
Fluorene	--	0.00005	ND
Heptachlor	0.0004	0.00001	ND
Heptachlor Epoxide	0.0002	0.00001	ND
Hexachlorobenzene	0.001	0.00005	ND
Hexachlorocyclopentadiene	0.05	0.00005	ND
Indeno(1,2,3-cd)Pyrene	--	0.00005	ND
Isophorone	--	0.0005	ND
Lindane	0.0002	0.00001	ND
Malathion	--	0.0001	ND
Methoxychlor	0.04	0.00005	ND
Metolachlor	--	0.00005	ND
Metribuzin	--	0.00005	ND
Molinate	--	0.0001	ND
Naphthalene	--	0.0001	ND
trans-Nonachlor	--	0.00005	ND
Parathion	--	0.0001	ND
Pendimethalin	--	0.0001	ND
Phenanthrene	--	0.00004	ND
Propachlor	--	0.00005	ND
Pyrene	--	0.00005	ND
Simazine	0.004	0.00005	ND
Terbacil	--	0.0001	ND
Terbutylazine	--	0.0001	ND
Thiobencarb	--	0.0001	ND
Trifluralin	--	0.0001	ND
EPA 531.2:			
Aldicarb (TEMIK)	--	0.0005	ND
Aldicarb sulfone	--	0.0005	ND
Aldicarb sulfoxide	--	0.0005	ND
Baygon (PROPOXUR)	--	0.0005	ND
Carbaryl	--	0.0005	ND
Carbofuran (FURADAN)	0.04	0.0005	ND
3-Hydroxycarbofuran	--	0.0005	ND
Methiocarb	--	0.0005	ND
Methomyl	--	0.0005	ND
Oxamyl (VYDATE)	0.2	0.0005	ND
EPA 547:			
Glyphosate	0.7	0.006	ND
EPA 548.1:			
Endothall	0.1	0.005	ND
EPA 549.2:			
Diquat	0.02	0.0004	ND
Paraquat	--	0.002	ND

ANALYSIS PERFORMED	MCL (mg/L)	RL (mg/L)	ETERNAL SPRING WATER (Produced from Proffit Spring Source)
EPA 1613: 2,3,7,8-TCDD (DIOXIN)	3x10 ⁻⁸	4.9x10 ⁻⁹	ND
Disinfection Byproducts EPA 300.1: Bromate EPA 300.1B: Chlorite	0.010 1.0	0.001 0.010	0.0021 ND
EPA 552.3: Bromochloroacetic acid Dibromoacetic acid Dichloroacetic acid Monobromoacetic acid Monochloroacetic acid Trichloroacetic acid Haloacetic Acids, Total	-- -- -- -- -- -- 0.060	0.001 0.001 0.001 0.001 0.002 0.001 0.002	ND ND ND ND ND ND ND
Disinfection Byproducts EPA 524.2: Total Trihalomethanes Bromodichloromethane Bromoform Chloroform Chlorodibromomethane	0.080 -- -- -- --	0.0005 0.0005 0.0005 0.0005 0.0005	ND ND ND ND ND
Residual Disinfectants SM4500-CL G: Residual Chlorine, Free Residual Chlorine, Total Chloramines	-- 4.0 4.0	0.05 0.05 0.05	ND ND ND
SM4500-CIO2-D: Chlorine Dioxide	0.8	0.24	ND
Miscellaneous EPA 331.0: Perchlorate	--	0.0005	ND

ANALYSIS PERFORMED	MCL (ng/L)	RL (ng/L)	ETERNAL SPRING WATER (Produced from Proffit Spring Source)
PFAs by EPA 537.1			
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid (11-Cl-PF3OUdS)	--	2.0 ng/L	ND
Hexafluoropropyleneoxide dimer acid (HFPO-DA)(Gen-X)(PFPrOPrA)	--	2.0 ng/L	ND
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid (9-Cl-PF3ONS)	--	2.0 ng/L	ND
N-Ethylperfluorooctane sulfonamido acetic acid (NEtFOSAA)	--	2.0ng/L	ND
N-Methylperfluorooctane sulfonamido acetic acid (NMeFOSAA)	--	2.0 ng/L	ND
Perfluorobutane sulfonic acid (PFBS)	--	2.0 ng/L	ND
Perfluorodecanoic acid (PFDA)	--	2.0 ng/L	ND
Perfluorododecanoic acid (PFDOA)	--	2.0 ng/L	ND
Perfluoroheptanoic acid (PFHpA)	--	2.0 ng/L	ND
Perfluorohexane sulfonic acid (PFHxS)	--	2.0 ng/L	ND
Perfluorohexanoic acid (PFHxA)	--	2.0 ng/L	ND
Perfluorononanoic acid (PFNA)	--	2.0 ng/L	ND
Perfluorooctane sulfonic acid (PFOS)	--	2.0 ng/L	ND
Perfluorooctanoic acid (PFOA)	--	2.0 ng/L	ND
Perfluorotetradecanoic acid (PFTDA)	--	2.0 ng/L	ND
Perfluorotridecanoic acid (PFTrDA)	--	2.0 ng/L	ND
Perfluoroundecanoic acid (PFUnDA)	--	2.0 ng/L	ND
4,8-Dioxa-3Hperfluorononanoic acid (DONA)	--	2.0 ng/L	ND

EPA approved methods were used in all of the analyses and a listing is available upon request. These test results may be used for compliance purposes as required.

¹ The EPA, some State agencies and/or the IBWA may have established alternate MCLs for some of these analytes. Please refer to Federal, State and Industry codes.

² Fluoride MCL is determined by annual average of maximum daily air temperatures where the bottled water is sold. Refer to tables found in 21 CFR 165. The MCL for bottled water to which Fluoride has been added is 0.7 mg/L.

³ Mineral water is exempt from allowable levels per 21 CFR 165.110(b)(3) and (4). The exemptions are aesthetically based allowable levels and do not relate to a health concern.

⁴ MCL established by US FDA for waters that meet the US FDA definition of "Purified" is 5-7 pH Units per the USP XXIII Standards, as referenced in 21 CFR 165.

⁵ The bottled water shall not contain beta particle and photon radioactivity from man-made radionuclides in excess of that which would produce an annual dose equivalent to the total body or any internal organ of 4 millirems per year calculated on the basis of an intake of 2 liters of the water per day (= 50 pCi/L).



ANALYTICAL REPORT

PREPARED FOR

Attn: (1201) Water Quality Manager
Eternal Water
455 Great Smoky Mountains Road
Newport, Tennessee 37821

Generated 5/6/2025 3:04:39 PM Revision 1

JOB DESCRIPTION

1201-941
Newport Springs - Newport - Spring Finished Product

JOB NUMBER

380-142252-1

Eurofins Eaton Analytical Pomona

Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Eaton Analytical, LLC Project Manager.

Compliance Statement

The report format being provided is not compliant with TNI (The NELAC Institute) Standards, and is a client-specific format

Authorization



Generated
5/6/2025 3:04:39 PM
Revision 1

Authorized for release by
Michelle Do, Project Manager
Michelle.Do@et.eurofinsus.com
(626)386-1102