

**Certificate of Analysis**

**Sample ID:** AHD4026-03  
**Sampled By:** BSK  
**Sample Description:** Spring

**Sample Date - Time:** 04/30/2024 - 11:50  
**Matrix:** Bottled Water  
**Sample Type:** Grab

**BSK Associates Laboratory Fresno**  
**General Chemistry**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Bromate	EPA 317.0	ND	1.0	ug/L	1	AHE0283	05/07/24	05/07/24	
Dichloramine (1)	SM 4500-Cl F	ND	0.10	mg/L	1	AHD1918	04/30/24 19:39	04/30/24	
Monochloramine (1)	SM 4500-Cl F	ND	0.10	mg/L	1	AHD1918	04/30/24 19:39	04/30/24	
Chloride	EPA 300.0	<b>6.4</b>	1.0	mg/L	1	AHD1917	05/01/24	05/01/24	
Chlorine, Free Residual (1)	SM 4500-Cl F	ND	0.10	mg/L	1	AHD1918	04/30/24 19:39	04/30/24	
Chlorine, Total Residual (1)	SM 4500-Cl F	ND	0.10	mg/L	1	AHD1918	04/30/24 19:39	04/30/24	
Chlorite	EPA 300.1	ND	0.0050	mg/L	1	AHE0281	05/08/24	05/08/24	
Surrogate: Dichloroacetate	EPA 300.1	106 %	<i>Acceptable range: 90-115 %</i>						
Color, Apparent	SM 2120B	ND	5.0	CU	1	AHD1907	04/30/24 17:20	04/30/24	
Color pH (1)	SM 4500-H+ B	<b>7.0</b>		pH Units	1	AHD1907	04/30/24	04/30/24	
Cyanide (total)	SM 4500-CN E	ND	5.0	ug/L	1	AHE0262	05/06/24	05/07/24	
Conductivity @ 25C	SM 2510B	<b>160</b>	1.0	umhos/cm	1	AHE0524	05/09/24	05/09/24	
Fluoride	EPA 300.0	ND	0.10	mg/L	1	AHD1917	05/01/24	05/01/24	
Langelier Index	SM 2330B	<b>-2.0</b>				AHE0881	05/14/24	05/14/24	
MBAS, Calculated as LAS, mol wt 340	SM 5540C	ND	0.050	mg/L	1	AHD1913	04/30/24 18:55	05/01/24	
Nitrate + Nitrite as N	EPA 300.0	<b>0.51</b>	0.23	mg/L	1	AHD1917	05/01/24 01:24	05/01/24	
Nitrate as N	EPA 300.0	<b>0.51</b>	0.23	mg/L	1	AHD1917	05/01/24 01:24	05/01/24	
Nitrite as N	EPA 300.0	ND	0.050	mg/L	1	AHD1917	05/01/24 01:24	05/01/24	
Threshold Odor	SM 2150B	ND	1.0	T.O.N.	1	AHD1903	04/30/24 16:45	04/30/24	
pH (1)	SM 4500-H+ B	<b>6.6</b>	0.0	pH Units	1	AHE0524	05/09/24 15:12	05/09/24	
pH Temperature in °C		<b>18.7</b>							
Sulfate as SO4	EPA 300.0	<b>6.2</b>	1.0	mg/L	1	AHD1917	05/01/24	05/01/24	
Total Dissolved Solids	SM 2540C	<b>130</b>	5.0	mg/L	1	AHE0075	05/01/24	05/01/24	
Turbidity	SM 2130B	<b>0.12</b>	0.10	NTU	1	AHD1907	04/30/24 17:38	04/30/24	

**Metals**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Aluminum	EPA 200.7	ND	50	ug/L	1	AHE0258	05/06/24	05/08/24	
Antimony	EPA 200.8	ND	2.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Arsenic	EPA 200.8	ND	2.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Barium	EPA 200.7	<b>56</b>	50	ug/L	1	AHE0258	05/06/24	05/08/24	
Beryllium	EPA 200.8	ND	1.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Cadmium	EPA 200.8	ND	1.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Calcium	EPA 200.7	<b>13</b>	0.10	mg/L	1	AHE0258	05/06/24	05/08/24	
Chromium	EPA 200.8	ND	10	ug/L	1	AHE0258	05/06/24	05/08/24	
Copper	EPA 200.8	ND	5.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Iron	EPA 200.7	ND	30	ug/L	1	AHE0258	05/06/24	05/08/24	
Lead	EPA 200.8	ND	1.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Magnesium	EPA 200.7	<b>3.9</b>	0.10	mg/L	1	AHE0258	05/06/24	05/08/24	
Manganese	EPA 200.7	ND	10	ug/L	1	AHE0258	05/06/24	05/08/24	
Nickel	EPA 200.8	ND	10	ug/L	1	AHE0258	05/06/24	05/08/24	
Potassium	EPA 200.7	<b>3.2</b>	2.0	mg/L	1	AHE0258	05/06/24	05/08/24	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

AHD4026 FINAL 06182024 1233

**Certificate of Analysis**

**Sample ID:** AHD4026-03  
**Sampled By:** BSK  
**Sample Description:** Spring

**Sample Date - Time:** 04/30/2024 - 11:50  
**Matrix:** Bottled Water  
**Sample Type:** Grab

**Metals**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Selenium	EPA 200.8	ND	2.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Silver	EPA 200.8	ND	10	ug/L	1	AHE0258	05/06/24	05/08/24	
Sodium	EPA 200.7	10	1.0	mg/L	1	AHE0258	05/06/24	05/08/24	
Thallium	EPA 200.8	ND	1.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Hardness as CaCO3	SM 2340B	50	0.41	mg/L					
Uranium	EPA 200.8	ND	1.0	ug/L	1	AHE0258	05/06/24	05/08/24	
Zinc	EPA 200.8	ND	50	ug/L	1	AHE0258	05/06/24	05/08/24	

**Organics**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<b><u>EDB and DBCP by GC-ECD</u></b>									
Ethylene Dibromide (EDB)	EPA 504.1	ND	0.020	ug/L	1	AHE0251	05/06/24	05/06/24	
Dibromochloropropane (DBCP)	EPA 504.1	ND	0.010	ug/L	1	AHE0251	05/06/24	05/06/24	
Surrogate: 1-Br-2-Nitrobenzene	EPA 504.1	104 %	Acceptable range: 70-130 %						
<b><u>Organohalide Pesticides and PCBs by GC-ECD</u></b>									
Aldrin	EPA 505	ND	0.075	ug/L	1	AHE0251	05/06/24	05/06/24	
Chlordane (Technical)	EPA 505	ND	0.10	ug/L	1	AHE0251	05/06/24	05/06/24	
Dieldrin	EPA 505	ND	0.020	ug/L	1	AHE0251	05/06/24	05/06/24	
Endrin	EPA 505	ND	0.10	ug/L	1	AHE0251	05/06/24	05/06/24	
Heptachlor	EPA 505	ND	0.010	ug/L	1	AHE0251	05/06/24	05/06/24	
Heptachlor Epoxide	EPA 505	ND	0.010	ug/L	1	AHE0251	05/06/24	05/06/24	
Hexachlorobenzene	EPA 505	ND	0.50	ug/L	1	AHE0251	05/06/24	05/06/24	
Hexachlorocyclopentadiene	EPA 505	ND	1.0	ug/L	1	AHE0251	05/06/24	05/06/24	
Lindane	EPA 505	ND	0.20	ug/L	1	AHE0251	05/06/24	05/06/24	
Methoxychlor	EPA 505	ND	10	ug/L	1	AHE0251	05/06/24	05/06/24	
PCB Aroclor Screen	EPA 505	ND	0.50	ug/L	1	AHE0251	05/06/24	05/06/24	
Toxaphene	EPA 505	ND	1.0	ug/L	1	AHE0251	05/06/24	05/06/24	
Surrogate: 1-Br-2-Nitrobenzene	EPA 505	104 %	Acceptable range: 70-130 %						
<b><u>Chlorinated Acid Herbicides by GC-ECD</u></b>									
2,4,5-T	EPA 515.4	ND	1.0	ug/L	1	AHE0425	05/08/24	05/10/24	
2,4,5-TP (Silvex)	EPA 515.4	ND	1.0	ug/L	1	AHE0425	05/08/24	05/10/24	
2,4-D	EPA 515.4	ND	10	ug/L	1	AHE0425	05/08/24	05/10/24	
Bentazon	EPA 515.4	ND	2.0	ug/L	1	AHE0425	05/08/24	05/10/24	
Dalapon	EPA 515.4	ND	10	ug/L	1	AHE0425	05/08/24	05/10/24	
Dicamba	EPA 515.4	ND	1.5	ug/L	1	AHE0425	05/08/24	05/10/24	
Dinoseb	EPA 515.4	ND	2.0	ug/L	1	AHE0425	05/08/24	05/10/24	
Pentachlorophenol	EPA 515.4	ND	0.20	ug/L	1	AHE0425	05/08/24	05/10/24	
Picloram	EPA 515.4	ND	1.0	ug/L	1	AHE0425	05/08/24	05/10/24	
Surrogate: DCPAA	EPA 515.4	98 %	Acceptable range: 70-130 %						
<b><u>Volatile Organics by GC-MS</u></b>									
1,1,1,2-Tetrachloroethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,1,1-Trichloroethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

AHD4026 FINAL 06182024 1233

**Certificate of Analysis**

**Sample ID:** AHD4026-03  
**Sampled By:** BSK  
**Sample Description:** Spring

**Sample Date - Time:** 04/30/2024 - 11:50  
**Matrix:** Bottled Water  
**Sample Type:** Grab

**Organics**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<b>Volatile Organics by GC-MS</b>									
1,1,2,2-Tetrachloroethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,1,2-Trichloro-1,2,2-trifluoroethane	EPA 524.2	ND	10	ug/L	1	AHE0110	05/02/24	05/02/24	
1,1,2-Trichloroethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,1-Dichloroethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,1-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,1-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,2,3-Trichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	B1.1
1,2,4-Trichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,2,4-Trimethylbenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,2-Dichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,2-Dichloroethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,2-Dichloropropane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,3,5-Trimethylbenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,3-Dichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,3-Dichloropropane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
1,4-Dichlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
2,2-Dichloropropane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
2-Butanone	EPA 524.2	ND	5.0	ug/L	1	AHE0110	05/02/24	05/02/24	
2-Chlorotoluene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
2-Hexanone	EPA 524.2	ND	10	ug/L	1	AHE0110	05/02/24	05/02/24	
4-Chlorotoluene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
4-Methyl-2-pentanone	EPA 524.2	ND	5.0	ug/L	1	AHE0110	05/02/24	05/02/24	
Acetone	EPA 524.2	ND	10	ug/L	1	AHE0110	05/02/24	05/02/24	
Benzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Bromobenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Bromochloromethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Bromodichloromethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Bromoform	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Bromomethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Carbon Tetrachloride	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Chlorobenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Chloroethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Chloroform	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Chloromethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
cis-1,2-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
cis-1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Dibromochloromethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Dibromomethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Dichlorodifluoromethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Dichloromethane	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Ethyl tert-Butyl Ether (ETBE)	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Ethylbenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Hexachlorobutadiene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Isopropylbenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

AHD4026 FINAL 06182024 1233

**Certificate of Analysis**

**Sample ID:** AHD4026-03  
**Sampled By:** BSK  
**Sample Description:** Spring

**Sample Date - Time:** 04/30/2024 - 11:50  
**Matrix:** Bottled Water  
**Sample Type:** Grab

**Organics**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<b><u>Volatile Organics by GC-MS</u></b>									
m,p-Xylenes	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Methyl-t-butyl ether	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Naphthalene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	B1.1
n-Butylbenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
n-Propylbenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
o-Xylene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
p-Isopropyltoluene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
sec-Butylbenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Styrene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
tert-Amyl Methyl Ether (TAME)	EPA 524.2	ND	3.0	ug/L	1	AHE0110	05/02/24	05/02/24	
tert-Butyl alcohol (TBA)	EPA 524.2	ND	2.0	ug/L	1	AHE0110	05/02/24	05/02/24	
tert-Butylbenzene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Tetrachloroethene (PCE)	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Toluene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
trans-1,2-Dichloroethene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
trans-1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Trichloroethene (TCE)	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Trichlorofluoromethane	EPA 524.2	ND	5.0	ug/L	1	AHE0110	05/02/24	05/02/24	
Vinyl Chloride	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Total 1,3-Dichloropropene	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Total Trihalomethanes		ND	0.50	ug/L					
Total Xylenes	EPA 524.2	ND	0.50	ug/L	1	AHE0110	05/02/24	05/02/24	
Surrogate: 1,2-Dichlorobenzene-d4	EPA 524.2	115 %							Acceptable range: 70-130 %
Surrogate: Bromofluorobenzene	EPA 524.2	116 %							Acceptable range: 70-130 %
<b><u>Semi-Volatile Organics by GC-MS</u></b>									
Alachlor	EPA 525.3	ND	1.0	ug/L	1	AHE0089	05/02/24	05/03/24	
Atrazine	EPA 525.3	ND	0.50	ug/L	1	AHE0089	05/02/24	05/03/24	
Benzo(a)pyrene	EPA 525.3	ND	0.10	ug/L	1	AHE0089	05/02/24	05/03/24	
Bis(2-ethylhexyl) adipate	EPA 525.3	ND	5.0	ug/L	1	AHE0089	05/02/24	05/03/24	
Bis(2-ethylhexyl) phthalate	EPA 525.3	ND	3.0	ug/L	1	AHE0089	05/02/24	05/03/24	
Bromacil	EPA 525.3	ND	10	ug/L	1	AHE0089	05/02/24	05/03/24	
Butachlor	EPA 525.3	ND	0.38	ug/L	1	AHE0089	05/02/24	05/03/24	
Diazinon	EPA 525.3	ND	0.25	ug/L	1	AHE0089	05/02/24	05/03/24	
Dimethoate	EPA 525.3	ND	10	ug/L	1	AHE0089	05/02/24	05/03/24	
Metolachlor	EPA 525.3	ND	0.50	ug/L	1	AHE0089	05/02/24	05/03/24	
Metribuzin	EPA 525.3	ND	0.50	ug/L	1	AHE0089	05/02/24	05/03/24	
Molinate	EPA 525.3	ND	2.0	ug/L	1	AHE0089	05/02/24	05/03/24	
Propachlor	EPA 525.3	ND	0.50	ug/L	1	AHE0089	05/02/24	05/03/24	
Simazine	EPA 525.3	ND	1.0	ug/L	1	AHE0089	05/02/24	05/03/24	
Thiobencarb	EPA 525.3	ND	1.0	ug/L	1	AHE0089	05/02/24	05/03/24	
Surrogate: 1,3-Dimethyl-2-nitrobenzene	EPA 525.3	90 %							Acceptable range: 70-130 %
Surrogate: Benzo(a)pyrene-d12	EPA 525.3	111 %							Acceptable range: 70-130 %
Surrogate: Triphenyl Phosphate	EPA 525.3	113 %							Acceptable range: 70-130 %

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

**Certificate of Analysis**

**Sample ID:** AHD4026-03  
**Sampled By:** BSK  
**Sample Description:** Spring

**Sample Date - Time:** 04/30/2024 - 11:50  
**Matrix:** Bottled Water  
**Sample Type:** Grab

**Organics**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
<b><u>Carbamates by HPLC</u></b>									
3-Hydroxycarbofuran	EPA 531.1	ND	3.0	ug/L	1	AHE0337	05/07/24	05/08/24	
Aldicarb	EPA 531.1	ND	3.0	ug/L	1	AHE0337	05/07/24	05/08/24	
Aldicarb Sulfone	EPA 531.1	ND	2.0	ug/L	1	AHE0337	05/07/24	05/08/24	
Aldicarb Sulfoxide	EPA 531.1	ND	3.0	ug/L	1	AHE0337	05/07/24	05/08/24	
Carbaryl	EPA 531.1	ND	5.0	ug/L	1	AHE0337	05/07/24	05/08/24	
Carbofuran	EPA 531.1	ND	5.0	ug/L	1	AHE0337	05/07/24	05/08/24	
Methomyl	EPA 531.1	ND	2.0	ug/L	1	AHE0337	05/07/24	05/08/24	
Oxamyl	EPA 531.1	ND	20	ug/L	1	AHE0337	05/07/24	05/08/24	
<b><u>Glyphosate by HPLC</u></b>									
Glyphosate	EPA 547	ND	25	ug/L	1	AHE0422	05/08/24	05/08/24	
Surrogate: AMPA	EPA 547	91 %	Acceptable range: 70-130 %						
<b><u>Endothall by GC-MS</u></b>									
Endothall	EPA 548.1	ND	45	ug/L	1	AHD1920	04/30/24	05/02/24	
<b><u>Diquat by HPLC</u></b>									
Diquat	EPA 549.2	ND	4.0	ug/L	1	AHE0094	05/02/24	05/14/24	
<b><u>Haloacetic Acids by GC-MS</u></b>									
Dibromoacetic Acid (DBAA)	EPA 552.3	ND	1.0	ug/L	1	AHE0093	05/02/24	05/02/24	
Dichloroacetic Acid (DCAA)	EPA 552.3	ND	1.0	ug/L	1	AHE0093	05/02/24	05/02/24	
Monobromoacetic Acid (MBAA)	EPA 552.3	ND	1.0	ug/L	1	AHE0093	05/02/24	05/02/24	
Monochloroacetic Acid (MCAA)	EPA 552.3	ND	2.0	ug/L	1	AHE0093	05/02/24	05/02/24	
Trichloroacetic Acid (TCAA)	EPA 552.3	ND	1.0	ug/L	1	AHE0093	05/02/24	05/02/24	
Total Haloacetic Acids		ND	2.0	ug/L					
Surrogate: 2-Bromobutanoic Acid	EPA 552.3	101 %	Acceptable range: 70-130 %						

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



**Certificate of Analysis**

**Sample ID:** AHD4026-03RE1  
**Sampled By:** BSK  
**Sample Description:** Spring

**Sample Date - Time:** 04/30/2024 - 11:50  
**Matrix:** Bottled Water  
**Sample Type:** Grab

**BSK Associates Laboratory Fresno**  
**General Chemistry**

Analyte	Method	Result	RL	Units	RL Mult	Batch	Prepared	Analyzed	Qual
Alkalinity as CaCO3	SM 2320B	78	3.0	mg/L	1	AHE0621	05/10/24	05/10/24	
Bicarbonate as CaCO3	SM 2320B	78	3.0	mg/L	1	AHE0621	05/10/24	05/10/24	
Carbonate as CaCO3	SM 2320B	ND	3.0	mg/L	1	AHE0621	05/10/24	05/10/24	
Hydroxide as CaCO3	SM 2320B	ND	3.0	mg/L	1	AHE0621	05/10/24	05/10/24	

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*