

CLIENT INFORMATION

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Client: *****

Requested On: Mar 23, 2026

Phone: *****

Email: *****

Questions? For fastest assistance:

support@mytapscore.com

Do not contact facility technicians directly.

TESTING PERFORMED
Testing Requested: Advanced Home Water Test

Matrix: Drinking Water

Testing / Report ID: E8X8WT

Testing Facility: Microbac Laboratories

Facility Location: 5680 West End Road
Arcata, California 95521

SAMPLE INFORMATION
Collection Date: Apr 7, 2026

Collected By: *****

Received Date: Apr 9, 2026

Reported On: Apr 16, 2026

Sample Location: Starbucks

Sample Address: *****

TESTING NOTES FROM TAP SCORE

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact support@mytapscore.com

SUMMARY ANALYSIS

ANALYTE	UNIT	RESULT	METHOD	EVALUATION
pH	pH	7.6	EPA 150.1	OK
Total Dissolved Solids	PPM	97.3	SM 2510 B	No benchmark available
Turbidity	NTU	0.8	EPA 180.1	No benchmark available
Hardness	PPM	21.2	SM 2340 B	No benchmark available
Expanded Hardness	PPM	21.3	Calculation	No benchmark available
Grains per gallon	Grains	1.24	Calculation	No benchmark available
Alkalinity (as CaCO ₃)	PPM	22.8	SM 2320 B	No benchmark available
Langelier Saturation Index		-1.88	Calculation	No benchmark available
Sodium Adsorption Ratio		0.841	Calculation	No benchmark available
Total THMs	PPB	NOT DETECTED	Calculation	No evaluation possible

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EVALUATION
1,1,1,2 Tetrachloroethane	PPB	NOT DETECTED	0.35	0.5	EPA 524.2	No evaluation possible
1,1,1 Trichloroethane	PPB	NOT DETECTED	0.29	0.5	EPA 524.2	No evaluation possible
1,1,2,2 Tetrachloroethane	PPB	NOT DETECTED	0.37	0.5	EPA 524.2	No evaluation possible
1,1,2 Trichloroethane	PPB	NOT DETECTED	0.36	0.5	EPA 524.2	No evaluation possible
1,1 Dichloroethane	PPB	NOT DETECTED	0.29	0.5	EPA 524.2	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. Tap Score maintains the right to enforce this and by accepting this report you agree to abide by this policy.

1,1 Dichloroethylene	PPB	NOT DETECTED	0.32	0.5	EPA 524.2	No evaluation possible
1,1 Dichloropropene	PPB	NOT DETECTED	0.31	0.5	EPA 524.2	No evaluation possible
1,2,3 Trichlorobenzene	PPB	NOT DETECTED	0.36	0.5	EPA 524.2	No evaluation possible
1,2,3 Trichloropropane	PPB	NOT DETECTED	0.31	0.5	EPA 524.2	No evaluation possible
1,2,4 Trichlorobenzene	PPB	NOT DETECTED	0.34	0.5	EPA 524.2	No evaluation possible
1,2,4 Trimethylbenzene	PPB	NOT DETECTED	0.36	0.5	EPA 524.2	No evaluation possible
1,2 Dichlorobenzene	PPB	NOT DETECTED	0.23	0.5	EPA 524.2	No evaluation possible
1,2 Dichloroethane	PPB	NOT DETECTED	0.3	0.5	EPA 524.2	No evaluation possible
1,2 Dichloropropane	PPB	NOT DETECTED	0.23	0.5	EPA 524.2	No evaluation possible
1,3,5 Trimethylbenzene	PPB	NOT DETECTED	0.41	0.5	EPA 524.2	No evaluation possible
1,3 Dichlorobenzene	PPB	NOT DETECTED	0.23	0.5	EPA 524.2	No evaluation possible
1,3 Dichloropropane	PPB	NOT DETECTED	0.31	0.5	EPA 524.2	No evaluation possible
1,4 Dichlorobenzene	PPB	NOT DETECTED	0.25	0.5	EPA 524.2	No evaluation possible
2,2 Dichloropropane	PPB	NOT DETECTED	0.41	0.5	EPA 524.2	No evaluation possible
Aluminum	PPM	NOT DETECTED	0.03	0.05	EPA 200.7	No evaluation possible
Antimony	PPM	NOT DETECTED	0.0003	0.005	EPA 200.8	No evaluation possible
Arsenic	PPM	Below Reporting Limit	0.0016	0.002	EPA 200.8	No evaluation possible
Barium	PPM	0.00294*	0.00037	0.005	EPA 200.8	No evaluation possible
Benzene	PPB	NOT DETECTED	0.3	0.5	EPA 524.2	No evaluation possible
Beryllium	PPM	NOT DETECTED	0.00013	0.001	EPA 200.8	No evaluation possible
Bicarbonate	PPM	27.7				No benchmark available
Boron	PPM	0.245	0.0026	0.02	EPA 200.7	< HGL
Bromobenzene	PPB	NOT DETECTED	0.31	0.5	EPA 524.2	No evaluation possible
Bromochloromethane	PPB	NOT DETECTED	0.32	0.5	EPA 524.2	No evaluation possible
Bromodichloromethane	PPB	NOT DETECTED	0.42	0.5	EPA 524.2	No evaluation possible
Bromoform	PPB	NOT DETECTED	0.43	0.5	EPA 524.2	No evaluation possible
Bromomethane	PPB	NOT DETECTED	0.33	0.5	EPA 524.2	No evaluation possible
Cadmium	PPM	NOT DETECTED	0.00011	0.001	EPA 200.8	No evaluation possible
Calcium	PPM	5.66	0.05	1	EPA 200.7	No benchmark available
Carbonate	PPM	0.0508				No benchmark available
Carbon Tetrachloride	PPB	NOT DETECTED	0.36	0.5	EPA 524.2	No evaluation possible
Chloride	PPM	7.65	0.14	0.5	EPA 300.0	No benchmark available
Chloride-to-Sulfate Mass Ratio		0.935				No benchmark available
Chlorobenzene	PPB	NOT DETECTED	0.24	0.5	EPA 524.2	No evaluation possible
Chloroethane	PPB	NOT DETECTED	0.3	0.5	EPA 524.2	No evaluation possible
Chloroform	PPB	NOT DETECTED	0.29	0.5	EPA 524.2	No evaluation possible
Chloromethane	PPB	NOT DETECTED	0.28	0.5	EPA 524.2	No evaluation possible
Chlorotoluene 2	PPB	NOT DETECTED	0.39	0.5	EPA 524.2	No evaluation possible
Chlorotoluene 4	PPB	NOT DETECTED	0.23	0.5	EPA 524.2	No evaluation possible
Chromium (Total)	PPM	NOT DETECTED	0.002	0.005	EPA 200.8	No evaluation possible
cis 1,2 Dichloroethylene	PPB	NOT DETECTED	0.25	0.5	EPA 524.2	No evaluation possible
cis 1,3 Dichloropropene	PPB	NOT DETECTED	0.32	0.5	EPA 524.2	No evaluation possible
Cobalt	PPM	NOT DETECTED	0.00031	0.005	EPA 200.8	No evaluation possible
Copper	PPM	0.0128	0.0011	0.005	EPA 200.8	< HGL
Dibromochloromethane	PPB	NOT DETECTED	0.21	0.5	EPA 524.2	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. Tap Score maintains the right to enforce this and by accepting this report you agree to abide by this policy.

Dibromochloropropane	PPB	NOT DETECTED	0.074	0.2	EPA 524.2	No evaluation possible
Dibromomethane	PPB	NOT DETECTED	0.26	0.5	EPA 524.2	No evaluation possible
Dichlorodifluoromethane	PPB	NOT DETECTED	0.41	0.5	EPA 524.2	No evaluation possible
Dichloromethane	PPB	NOT DETECTED	0.25	0.5	EPA 524.2	No evaluation possible
E. coli	P/A	NOT DETECTED			SM 9223B	No evaluation possible
Ethylbenzene	PPB	NOT DETECTED	0.33	0.5	EPA 524.2	No evaluation possible
Ethylene dibromide	PPB	NOT DETECTED	0.0097	0.05	EPA 524.2	No evaluation possible
Fluoride	PPM	0.137	0.041	0.1	EPA 300.0	< HGL
Hexachlorobutadiene	PPB	NOT DETECTED	0.33	0.5	EPA 524.2	No evaluation possible
Iron	PPM	NOT DETECTED	0.016	0.05	EPA 200.7	No evaluation possible
Isopropylbenzene	PPB	NOT DETECTED	0.31	0.5	EPA 524.2	No evaluation possible
Lead	PPM	NOT DETECTED	0.00016	0.001	EPA 200.8	No evaluation possible
Lithium	PPM	0.0112*	0.0029	0.05	EPA 200.7	No evaluation possible
Magnesium	PPM	1.71	0.0061	1	EPA 200.7	No benchmark available
Manganese	PPM	NOT DETECTED	0.0013	0.005	EPA 200.8	No evaluation possible
Mercury	PPM	NOT DETECTED	0.0001	0.001	EPA 200.8	No evaluation possible
Methyl Tertiary Butyl Ether	PPB	NOT DETECTED	0.46	3	EPA 524.2	No evaluation possible
Molybdenum	PPM	0.00274*	0.002	0.005	EPA 200.8	No evaluation possible
m,p Xylene	PPB	NOT DETECTED	0.39	0.5	EPA 524.2	No evaluation possible
Naphthalene	PPB	NOT DETECTED	0.49	0.5	EPA 524.2	No evaluation possible
n Butylbenzene	PPB	NOT DETECTED	0.45	0.5	EPA 524.2	No evaluation possible
Nickel	PPM	0.00368*	0.0007	0.005	EPA 200.8	No evaluation possible
Nitrate (as N)	PPM	0.137	0.027	0.1	EPA 300.0	< HGL
Nitrite (as N)	PPM	NOT DETECTED	0.027	0.1	EPA 300.0	No evaluation possible
n Propylbenzene	PPB	NOT DETECTED	0.3	0.5	EPA 524.2	No evaluation possible
o Xylene	PPB	NOT DETECTED	0.34	0.5	EPA 524.2	No evaluation possible
Phosphorus	PPM	NOT DETECTED	0.01	0.02	EPA 200.7	No evaluation possible
p Isopropyltoluene	PPB	NOT DETECTED	0.43	0.5	EPA 524.2	No evaluation possible
Potassium	PPM	0.758*	0.182	1	EPA 200.7	No evaluation possible
sec Butylbenzene	PPB	NOT DETECTED	0.43	0.5	EPA 524.2	No evaluation possible
Selenium	PPM	NOT DETECTED	0.0044	0.005	EPA 200.8	No evaluation possible
Silica	PPM	4.01	0.16	0.235	EPA 200.7	No benchmark available
Silver	PPM	NOT DETECTED	0.00063	0.001	EPA 200.8	No evaluation possible
Sodium	PPM	8.9	0.22	1	EPA 200.7	No benchmark available
Specific Conductivity	umhos/cm	165	2	2	SM 2510 B	No benchmark available
Strontium	PPM	0.0415	0.00011	0.001	EPA 200.7	< HGL
Styrene	PPB	NOT DETECTED	0.26	0.5	EPA 524.2	No evaluation possible
Sulfate	PPM	8.18	0.29	1	EPA 300.0	< HGL
tert Butylbenzene	PPB	NOT DETECTED	0.39	0.5	EPA 524.2	No evaluation possible
Tetrachloroethylene	PPB	NOT DETECTED	0.32	0.5	EPA 524.2	No evaluation possible
Thallium	PPM	NOT DETECTED	0.00012	0.001	EPA 200.8	No evaluation possible
Tin	PPM	NOT DETECTED	0.00022	0.005	EPA 200.8	No evaluation possible
Titanium	PPM	0.00072*	0.00061	0.005	EPA 200.7	No evaluation possible
Toluene	PPB	NOT DETECTED	0.25	0.5	EPA 524.2	No evaluation possible
Total Coliform	P/A	NOT DETECTED			SM 9223B	No evaluation possible

Use of this report can only be done in full, with no alterations or additions. Tap Score maintains the right to enforce this and by accepting this report you agree to abide by this policy.

trans 1,3 Dichloropropene	PPB	NOT DETECTED	0.37	0.5	EPA 524.2	No evaluation possible
Trichloroethylene	PPB	NOT DETECTED	0.23	0.5	EPA 524.2	No evaluation possible
Trichlorofluoromethane	PPB	NOT DETECTED	0.27	0.5	EPA 524.2	No evaluation possible
Uranium	PPM	0.000056*	3.0E-5	0.001	EPA 200.8	No evaluation possible
Vanadium	PPM	NOT DETECTED	0.00053	0.005	EPA 200.8	No evaluation possible
Vinyl Chloride	PPB	NOT DETECTED	0.34	0.5	EPA 524.2	No evaluation possible
Zinc	PPM	0.0351	0.0012	0.01	EPA 200.7	< HGL

How To Read Your Tap Score PDF Report

Your results are being evaluated against the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: The Method Detection Limit is the lowest concentration which the analysis team and instrumentation is configured to measure.

RL: The Method Reporting Limit is the lowest level at which the laboratory can confidently and accurately quantify the concentration.

*Analyte was detected below the reporting limit. The value shown is an estimate.



Did you know?

This Tap Score report is easier to understand when viewed online. Access in-depth information about every detection, including health risks and treatment solutions.

app.mytapscore.com/signin